



c103



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F6/DFS/MS/GH/SZ/2026/ 447

Dated: 08/05/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s TE New Delhi (A unit of TE Hospitality and Estates Ltd.), located at A-3, Pamposh Enclave, Greater Kailash-1, New Delhi 110048. comprised of Basement, Stilt, Ground & 03 Upper Floors. Owned/Occupied by M/s TE New Delhi (A unit of TE Hospitality and Estates Ltd.), was earlier issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/GH/2023/SZ/58 dated 01/03/2023. The premises was re-inspected by the officer concerned of this department on 24/04/2026. in the presence Sh. Rajeev Kumar and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for Residential & Lodging, "Group-A" (Guest House), (Guest House running at Basement-(Storage), Stilt (Parking), Ground (Reception + Lounge), First Floor to Third Floor (08 Guest Rooms on each Floors). (Total 24 Guest Rooms only) with effect from 08/05/2026 for a period of 03 Three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on08/05/2026 at New Delhi by.

(A.K. Malik)
Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002.-to ensure the occupancy as detailed above & deviation if any.
2. The Owned/Occupied, M/s TE New Delhi (A unit of TE Hospitality and Estates Ltd.), located at A-3, Pamposh Enclave, Greater Kailash-1, New Delhi 110048. (Online Portal ID No. 2026041104837 dated- 11/04/2026.)

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. Basement shall be used as per building bylaws strictly.

INSPECTION REPORT				
1. Name & address of the building	M/s TE New Delhi (A unit of TE Hospitality and Estates Ltd.), located at A-3, Pamposh Enclave, Greater Kailash-1, New Delhi 110048.			
2. Type of Occupancy	Residential & Loading, "Group-A" (Guest House), Comprised of Basement, Stilt, Ground & 03 Upper Floors (Guest House running at Basement-(Storage), Stilt (Parking), Ground (Reception + Lounge), First Floor to Third Floor (08 Guest Rooms on each Floors). Total 24 Guest Rooms.			
3. Type of Case	Renewal			
4. Details of Previous NOC	F.6/DFS/MS/GH/2023/SZ/58 dated 01/03/2023			
5. Fire Safety directives letter No	Nill			
6. Date of inspection	24/04/2026			
7. Name of Inspecting Officer	Sh. Sarabjeet Singh ADO (BCP)			
8. Name and designation of officers From the building side	Sh. Rajeev Kumar			
9. Year of Construction	2010 (As per online application)			
10. Applicant's letter No.	Online-ID No – 2026041104837 dated- 11/04/2026.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC/ Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09m	09m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 Nos	Provided	MR
	• Basements	02 Nos	Provided	MR
	b. Width of staircases			
	• Upper Floor	Required	1.28m & 0.78m	MR (old case)
	• Basements	Required	1.28m & 0.78m	MR (old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	Required	02nos.	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	Required	Provided	MR
3.	Compartmentation			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management system.	As per clause 7.31 in UBBL-2016		
	a) Basements	Required	Exhaust fan provided	MR
	b) Upper floors	Required	Provided	MR
5.	Fire Extinguishers.			
	a) Total numbers	10 nos.	10 nos. Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI market	Provided	MR

6.	First Aid Hose Reels.			
	a) Total numbers on each floor	One	Provided	NMR
	b) Length of hose reel hose	30m	Provided	MR
	c) Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection & alarming system. As per clause 7.31 in UBBL-2016			
	a) Type of detectors	CO	Provided	MR
	b) Location of Main Panel	Required	Provided	MR
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	Required	Provided	MR
8.	MOEFA			
		Required	Provided	MR
9.	Public Address System			
		Required	Provided	MR
10.	Automatic Sprinkler System			
	a) Basement			
	b) Ground & Upper Floors	Required	Provided	MR
	c) Sprinkler above false ceiling	NA	Provided	NA
11.	Internal Hydrants			
	a) Size of riser/down-comer	100mm	Provided	MR
	b) Number of hydrants per floor	01nos.	Provided	MR
	c) Hose Box	01nos.	Provided	MR
12.	Yard Hydrants			
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900LPM & 180LPM	Provided	MR
	➤ Head of the pump	44.5m & 30m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs	10,000 ltrs	MR
15.	Exit Signage.			
		Required	Provided	MR

16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	Fire Control Room			
	a) Detector System Panel	NA	Provided	NA
	b) Flow Switch Panel	NA	NA	NA
	c) PA System Panel	NA	Provided	NA
	d) Battery backup	NA	Provided	NA
	e) Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were randomly checked and found functional at the time of inspection. Earlier shortcomings issued by this department vide letter No. F.6/DFS/MS/GH/2024/SZ/184 dated 30/04/2024, have been rectified.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/GH/2023/SZ/58 dated 01/03/2023, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signatures please.

Last Date of Disposal 09/05/2026.

Name - Sarabjeet Singh
Designation - ADO(BCP)

DO (SD)

28/4/24

CFD

A.K. MAIK

Principal Officer

CFD to Secy.

24/05/26

CFD (SZ)