

d25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No: F6/DFS/MS/SCHOOL/2025/ 952

Dated: 07/08/2025

FIRE SAFETY CERTIFICATE

Certified that The Adarsh Public School , located at Kirti Nagar, New Delhi 110015 comprised of Ground Floor + 03 upper Floors, Owned/Occupied by The Adarsh Public School , was issued FSC Vide letter no. F6/DFS/MS/School/WZ/2022/702 dated 24/06/2022. The premises was re-inspected by the officer concerned of this department on 20/07/2025 in the presence of Sh. A.K. Sahgal and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17/01/2005 and found that the building/premises is fit for occupancy class "Educational" Group B with effect from 07/08/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions mentioned below.

Issued on 07/08/2025 at New Delhi by.


Virendra Singh
(Chief Fire Officer)

Copy to:-

1. The Director, Directorate of Education, Old Secretariat, New Delhi-110054.
2. The Principal, The Adarsh Public School , located at Kirti Nagar, New Delhi 110015.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good Working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1.	Name & address of the building	The Adarsh School, located at Kirti Nagar, New Delhi-110018.
2.	Type of Occupancy	Educational (Ground + 03 Upper Floor)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2022/702 dated 24/06/2022.
5.	Fire Safety directives letter No	DOE Circular 262-362 dated 17/01/2005
6.	Date of inspection	20/07/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. A.K. Sahgal
9.	Year of Construction	1998 (As per previous inspection report dated 10/06/2022)
10.	Applicant's letter No.	Outdoor diary No. 2833 dated 18/06/2025.

The said school building comprised of ground + 03 upper floor, was issued FSC vide letter no. F6/DFS/MS/School/WZ/2022/702 dated 24/06/2022.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 m	1.35 m & 01 ramp 1.15 m	MR old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	01 m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	10 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7	Automatic fire detection and alarming system.		
	• Type of detectors	NA	NA
	• Location of Main Panel	NA	NA
	• Location of Repeater Panel	NA	NA
	• Alternate source of power	NA	NA
	• Hooters' Location	NA	NA
8	MOEFA	Required	Provided
9	Public Address System.	Required	Provided
10	Automatic Sprinkler System.		
	• Basement	NA	NA
	• Upper Floor	NA	NA
	• Sprinkler above false ceiling	NA	NA
11	Internal Hydrants		
	• Size of riser/down-comer	100 mm	Provided
	• Number of hydrants per floor	01	Provided
	• Hose Box	01	Provided
12	Yard Hydrants.		
	• Total number of hydrants	NA	NA
	• Hose Box	NA	NA
13	Pumping Arrangements.		
	• Ground Level		
	➤ Discharge of main Pump	NA	NA
	➤ Head of Main pump	NA	NA
	➤ Number of main pumps	NA	NA
	➤ Jockey Pump out put	NA	NA
	➤ Jockey pump head	NA	NA
	➤ Standby Pump out put	NA	NA
	➤ Standby Pump Head	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA
	➤ Pump House Access	NA	NA
	• Terrace level		
	➤ Discharge of pump	450 LPM	Provided
	➤ Head of the pump	30 m	Provided
	➤ Power Supply	Required	Provided
	➤ Auto Starting of pump	Required	Provided
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	NA	NA
	➤ Draw-off connection	NA	NA
	➤ Fire service inlet	Required	Provided
	➤ Access to tank	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided
15	Exit Signage.	Required	Provided
16	Provision of Lifts.		
	• Pressurization of Lift Shaft	NA	NA
	• Pressurization of Lift lobby	NA	NA
	• Communication In lift Car	NA	NA
	• Fireman's Grounding Switch	NA	NA
	• Lift Signage	NA	NA

Standby power supply		Required	Provided	MR
Refuge Area.				
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection system provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/EH/2021/MN/WZ/36 dated 18/02/2021 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

38/ADO/MN
21/07/2025

~~Dy CRO (WZ)~~

~~SAP~~
21/7/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

CFO/... 23/07/2025
Dated...

~~dy~~
23/7

~~CFO~~
28/7/2025

~~Principal Director~~

CFO + Jsm.

~~29/07/25~~

~~CFO~~
31/7/2025

ADO (MN)

Sir, R-T is put up for your kind perusal & signature pls.

~~SAP~~
31/7/2025

~~CFO~~
31/8/2025