

c/163

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/EH/NDZ/2025/ 358

Dated 02/09/2025

To,

The Commissioner,
Municipal Corporation of Delhi,
New Delhi.

Sub: Inspection report in respect of The Art of Dumpling(A unit of Kahhak Industries Pvt. Ltd.), at G-18, Block-G, Ground floor Marina Arcade, Outer Circus, Connaught Place, New Delhi-110001..

Sir,


Please refer to your online application ID. No. 2025072811949 dated 30/07/2025, on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 14/08/2025 in the presence of Sh. Krishan Kumar to check the Fire safety arrangements provided in the building.

During inspection, it was observed that the restaurant is running at ground floor, in a building comprised of ground + 02 upper floors. Fire safety arrangements such as fire extinguishers, first-aid hose reel, MOEFA, pumping arrangement & exit signage etc, are provided. However, following shortcomings were observed:-

1. First aid hose reel is provided but not functional due to badly damage.
2. MOEFA is provided but not functional.
3. Exit signage is found removed.

In view of above shortcomings, the application for renewal fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer



Copy to: -

1. The Owner/Occupier, The Art of Dumpling(A unit of Kahhak Industries Pvt. Ltd.), at G-18, Block-G, Ground floor Marina Arcade, Outer Circus, Connaught Place, New Delhi-110001..