

c/52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

Dated: 03/07/2025

No.F6/DFS/MS/School/NDZ/2025/ 565

To

The Principal,
The Bengali Senior Sec. School,
22-A, Shyam Nath Marg, Delhi- 110054.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **The Bengali Senior Sec. School**
located at **22-A, Shyam Nath Marg, New Delhi- 110054.**

Sir,

This has reference to your letter No. nil dated nil received in this department on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 01.07.2025 in the presence of Mrs. Rachna (Principal) and it was observed that building is divided into two blocks 1. (ground + 01 upper floor) & 2. (ground floor only). During the inspection, following shortcomings were observed:-

1. First aid hose reel provided but not functional.
2. Fire pump not on auto start mode.
3. Exit signages are not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.

o/c 01/07/25
sa 27/