



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7-33
आग दोन
ममन महोदय

No. F6/DFS/MS/EH/2025/ 79

Dated:- 04/03/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s. The Big Chill (A Unit of Big Chill Café Pvt. Ltd.), Located at, Shop No. 315, 316, Second Floor, DLF Promenade Mall, Vasant Kunj, Delhi-110070, restaurant is running at Second Floor only in a building comprised of 02 tier Basement + Ground + 02 Upper Floors owned/occupied by M/s. The Big Chill (A Unit of Big Chill Café Pvt. Ltd.) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 25/02/2025 in the presence Sh. Imran (Manager) and that the premises is fit for occupancy class "Assembly" Group D (Restaurant) for Second Floor only with effect from 04/03/2025 and valid 31/03/2028 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 04/03/2025 at New Delhi by.

(Atul Garg)
Director
Tel No. 011-23414000

Copy to:-

1. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi in r/o computer id no. 2024100415220 dated 11/02/2025
2. The Dy. Health Officer, Delhi Municipal Corporation, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016.
3. The Authorized Signatory, M/s. The Big Chill A Unit of Big Chill Café Pvt. Ltd., Shop No. 315, 316, Second Floor, DLF Promenade Mall, Vasant Kunj, Delhi-110070..

Following fire safety directives must be adhered to:-

1. This FSC is valid for restaurant area's Second Floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: **M/s. The Big Chill A Unit of Big Chill Café Pvt. Ltd.** Located at Shop No. 315, 316, 2nd floor, **DLF Promenade Mall, Vasant Kunj, Delhi-110070**
 2. Type of Occupancy : Assembly Building "Group-D" Restaurant
 3. Type of Case : New
 4. Details of previous NOC : F6/DFS/MS/EH/2022/SZ/169 dated 10/06/2022
{earlier FSC issued to M/s Nandos (A Unit of Nandos Karnataka Restaurant Pvt. Ltd.)}
 5. Fire Safety directives Letter No. : UBBL-2016
 6. Date of inspection : 25/02/2025
 7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
 8. Name and designation of Officer from the building side : Sh. Imran (Manager)
 9. Year of Construction : 2004 (As mentioned in online application)
 10. Applicant's online id no. : 2024100415220 dated 11/02/2025
- The building is comprised of 02 tier Basement + Ground + 02 Upper Floors but restaurant is running at 2nd floor only.

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Requirements | Provided at site | Remarks MR/NMR |
|------|---|---|----------------------|----------------|
| 1. | Access of building FSC No. F.6/DFS/MS/Mall/2022/SZ/464 dated 19/10/2022 of DLF Promenade Mall | | | |
| | • Road width | Restaurant within Mall | As above | MR |
| | • Gate width | Restaurant within Mall | As above | N/A |
| | • Width of internal road | Restaurant within Mall | As above | N/A |
| 2. | Number, width, Type & Arrangements of exits Provided & Maintained by DLF Promenade mall | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 02 nos. | As above | MR |
| | • Basements | N/A | As above | N/A |
| | b. Width of staircases | Provided & Maintained by DLF Promenade mall | | |
| | • Upper floors | Required | As above | MR |
| | • Basements | N/A | As above | N/A |
| | c. Protection of exits | Provided & Maintained by DLF Promenade mall | | |
| | • Fire check door | Required | As above | MR |
| | • Pressurization | N/A | As above | N/A |
| | d. No of continuous staircase to terrace | Required | As above | MR |
| | e. Width Of Corridor | N/A | N/A | N/A |
| | f. Door Size | 1.5 m each | 1.50 m & 1.50 m | MR |
| 3. | Compartmentation Provided & Maintained by DLF Promenade mall | | | |
| | • Fire check door | Required | As above | MR |
| | • Sealing of electrical shafts | N/A | As above | N/A |
| | • Fire Rating of shaft door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke managements System Provided & Maintained by DLF Promenade mall | | | |
| | • Basements | N/A | N/A | N/A |
| | • Upper floors | Required | Exhaust Fan Provided | MR |

| | | | | |
|-----|--|---|--------------------|-----|
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 06 nos. | Provided | MR |
| | • Types | ABC & CO ₂ | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |
| 6. | First – Aid Hose Reels | Provided & Maintained by DLF Promenade mall | | |
| | • Total numbers on each floor | Required | 01 in restaurant | MR |
| | • Length of hose reel hose | Required | 30 m | MR |
| | • Nozzle diameter | Required | 05 mm | MR |
| 7. | Automatic fire detection and alarming system | Provided & Maintained by DLF Promenade mall | | |
| | • Type of detectors | Required | Smoke & Heat | MR |
| | • Location of Main Panel | Required | As above | MR |
| | • Location of Repeater Panel | N/A | N/A | N/A |
| | • Alternate source of power | Required | As above | MR |
| | • Hooters' Location | Required | As above | MR |
| 8. | MOEFA | Required | As above | MR |
| 9. | Public Address System | Required | As above | MR |
| 10. | Automatic Sprinkler System | Provided & Maintained by DLF Promenade mall | | |
| | • Basements | Required | As above | MR |
| | • Upper Floor | Required | Provided in Restt. | MR |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants: | Provided & Maintained by DLF Promenade mall | | |
| | • Size of riser/down- comer | Required | As above | MR |
| | • Number of hydrants per floor | Required | As above | MR |
| | • Hose Box | Required | As above | MR |
| 12. | Yard Hydrants | Provided & Maintained by DLF Promenade mall | | |
| | • Total number of hydrants | N/A | As above | N/A |
| | • Hose Box | N/A | As above | N/A |
| 13. | Pumping Arrangements: | Provided & Maintained by DLF Promenade mall | | |
| | • Ground Level | 4500 lpm | As above | MR |
| | • Discharge of main pump | 70 m | As above | MR |
| | ➤ Head of main pump | 02 | As above | MR |
| | ➤ Number of main pumps | 180 lpm | As above | MR |
| | ➤ Jockey pump out put | 70 m | As above | MR |
| | ➤ Jockey pump head | 4500 lpm | As above | MR |
| | ➤ Standby Pump out put | 70 m | As above | MR |
| | ➤ Standby Pump Head | Required | As above | MR |
| | ➤ Auto Staring/Manual stopping | Required | As above | MR |
| | ➤ Pump House Access | Provided & Maintained by DLF Promenade mall | | |
| | • Terrace level | N/A | N/A | N/A |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the pump | N/A | N/A | N/A |
| | ➤ Power supply | N/A | N/A | N/A |
| | ➤ Auto starting of pump | N/A | N/A | N/A |
| 14. | Captive water Storage for firefighting: | Provided & Maintained by DLF Promenade mall | | |
| | • Underground tank capacity | 4,60,000 ltrs | As above | MR |
| | ➤ Draw off connection | Required | As above | MR |
| | ➤ Fire service inlet | Required | As above | MR |
| | ➤ Access to tank | Required | As above | MR |
| | • Overhead Tank capacity | 30,000 ltrs | As above | MR |
| 15. | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | Provided & Maintained by DLF Promenade mall | | |
| | ➤ Pressurization of Lift Shaft | N/A | N/A | N/A |
| | ➤ Pressurization of lift lobby | N/A | N/A | N/A |
| | ➤ Communication in lift Car | N/A | N/A | N/A |
| | ➤ Fireman's Grounding Switch | N/A | N/A | N/A |

| | | | | |
|-----|--|---|-------------------|-----|
| | ➤ Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | Required | Provided (DG Set) | MR |
| 18. | Refuge Area | | | |
| | ➤ Total area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire control room | Provided & Maintained by DLF Promenade mall | | |
| | ➤ Detector system panel | N/A | As above | N/A |
| | ➤ Flow Switch Panel | N/A | As above | N/A |
| | ➤ PA System Panel | N/A | As above | N/A |
| | ➤ Battery backup | N/A | As above | N/A |
| | ➤ Building Floor Plans | N/A | As above | N/A |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | N/A | As above | N/A |

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, grant of Fire Safety Certificate is recommended under rule 35 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

Accordingly, DFA is prepared & put up for approval please.

Aman Kumar Lathar
ADO (JWP)

AO (SD)

AO (JWP)

28/01/2025

Director

AO (JWP)

Spec. F.S. letter is put-up for your signature pl.

Director

AO (JWP)

uploaded
08/03/25