



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/2025/School/ 1233

Dated: 06/10/2025

FIRE SAFETY CERTIFICATE

Certified that the Bud's Paradise School located at Pusta Road, Sant Nagar, Burari, Delhi-110084 comprised of Ground & 03 upper floors owned/ occupied by Bud's Paradise School was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/School/2022/756 dated 14/07/2022. The premise was inspected by the officer concerned of this department on 26/09/2025 in the presence of Sh. Kailash Kumar (Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under "Group B Educational (School)" with effect from 06/10/2025 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 06/10/2025 at New Delhi by.

M.K. Chattopadhyay
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.
2. The Manager, Bud's Paradise School located at Pusta Road, Sant Nagar, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Bud's Paradise School, Pusta Road, Sant Nagar, Burari, Delhi-110084.
2. Type of Occupancy : Educational
3. Composition of building : Ground plus 03 upper floors
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2022/756 dated 14/07/2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 26/09/2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Kailash Kumar (Manager)
10. Year of Construction : 2005 & 2007
11. Applicant's letter No. : Letter No. Nil & DFS Dairy No.6215 dated 19/09/2025

S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per Rules 35 (6)	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06m Directly Accessible NA	06m Directly Accessible NA	MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	01 NA	02 NA	MR (being old case) NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	1.50m NA	1.50 & .0.92m NA	MR (being old case) NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	01m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA	NA NA NA NA	NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	NA Required	NA Natural Ventilated	NA MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	09nos ABC/Co2 ISI Marked	15nos ABC--15 Yes	MR MR MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01	01	MR
	• Hose Box	01	01	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump			
	➤ Head of the pump	450 LPM	450 LPM	MR
	➤ Power Supply	40m	40m	MR
➤ Auto Starting of pump	NA	NA	NA	
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 LTR	10,000 LTR	MR

Exit Signage		Required		Provided	MR
16	Provision of Lifts.				
	• Pressurization of Lift Shaft	N/A		N/A	
	• Pressurization of Lift lobby	N/A		N/A	N/A
	• Communication In lift Car	N/A		N/A	N/A
	• Fireman's Grounding Switch	N/A		N/A	N/A
	• Lift Signage	N/A		N/A	N/A
17	Standby power supply	N/A		N/A	N/A
18	Refuge Area.				
	➤ Total Area	N/A		N/A	N/A
	➤ Location	N/A		N/A	N/A
19	Fire Control Room				
	• Detector System Panel	N/A		N/A	N/A
	• Flow Switch Panel	N/A		N/A	N/A
	• PA System Panel	N/A		N/A	N/A
	• Batter backup	N/A		N/A	N/A
	• Building Floor Plans	N/A		N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A		N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, it is **recommended for renewal of fire safety certificate** issued vide this department letter of even no. F6/DFS/MS/School/2022/756 dated 14/07/2022.

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation :- ADO/RN

Dy. CFO (WZ)

CFO

Principal Director

ADO (RN)

As approved, F.T. letter is put up for your signature please

Dy CFO (WZ)

MS cell

Dy. CFO to School

Dy. CFO (WZ)

03/10/2025