

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2025/ 86

Dated 15/02/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Sub:- Inspection report in respect of The Corner Point, Located at 8210A, Multani Dhanda, Paharganj, New Delhi- 110055.

Sir,

Please refer to your Online Application ID. No. 2025012000744 dated 20/01/2025, on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 11/02/2025 in the presence of Sh Rajiv Trehan to check the Fire safety arrangements.

During inspection, it was observed that the Guest house is running at Ground + 03 Upper Floors, in a building Comprised of ground + 04 upper Floors, Ground Floor (Commercial Shops), 1st Floor (03 Guest Rooms), 2nd Floor (04 Guest Rooms), 3rd Floor (05 Guest rooms), (Total 12 Guest Rooms), The owner/occupier has given an undertaking/affidavit on dated 31/12/2019 regarding not to use any floor above third floor. Fire safety arrangements such as Fire Extinguishers, First-Aid Hose Reel, MOEFA, Pumping Arrangement & Exit Signage etc, are provided. However, following shortcomings were observed:-

1. First-Aid hose reel are provided but not functional.
2. MOEFA is provided but not functional.
3. Public Address System is provided but not functional.
4. Terrace level main fire pump capacity of 225 LPM pump is provided but not functional.

In view of above shortcomings, the application for renewal fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Copy to: -

1. The Dy. Health Officer, Karol Bagh Zone, Anand Parbat, New Delhi.
2. The Owner/Occupier The Corner Point, 8210A, Multani Dhanda, Paharganj, New Delhi- 110055.