



C 7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F.6/DFS/MS/EH/SZ/2026/ 448

Dated: 08/05/2026

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of M/s. The Drop (A unit of Pass Code Hospitality Pvt. Ltd.), located at G-8, Ground Floor, Hauz Khas Market, Hauz Khas, New Delhi-110016, comprised of Ground, Mezzanine and + 02 Upper Floors. Owned/Occupied by M/s. The Drop (A unit of Pass Code Hospitality Pvt. Ltd.), was inspected by the officer concerned of this department on 24/04/2026 in the presence Sh. Rajiv Kumar and found that the said premise has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy Class "Assembly" (Group-D) (Restaurant at Ground Floor only) with effect from 08/05/2026 for a period of 03 Three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 08/05/2026 at New Delhi by

(A.K. Malik)
Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002. - to ensure the occupancy as detailed above & deviation if any
2. The Owned/Occupied, M/s. The Drop (A unit of Pass Code Hospitality Pvt. Ltd.), located at G-8, Ground Floor, Hauz Khas Market, Hauz Khas, New Delhi-110016. (Online Portal ID No. - 2026040904665 dated 09/04/2026).

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. **Mezzanine Floor shall be used for storage purpose only. Violation of the above FSC shall be stained null & void automatically.**

INSPECTION REPORT

1. Name & address of the building	M/s. The Drop (A unit of Pass Code Hospitality Pvt. Ltd.), located at G-8, Ground Floor, Hauz Khas Market, Hauz Khas, New Delhi-110016.			
2. Type of Occupancy	Assembly (Group-D), (Restaurant at Ground floor only), building comprised of Ground, Mezzanine, and Two Upper Floors only.			
3. Type of Case	New Case			
4. Details of Previous NOC	Nil			
5. Fire Safety directives letter No	Nil			
6. Date of inspection	24/04/2026			
7. Name of Inspecting Officer	Sh. Sarabjeet Singh ADO (BCP)			
8. Name and designation of officers From the building side	Sh. Rajiv Kumar			
9. Year of Construction	1996 (As per online application)			
10. Applicant's letter No.	Online-ID No – 2026040904665 dated 09/04/2026			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Required as per UBBL/NBC-Part-IV	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06m	Provided	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	06m	Provided	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2x1.5m	2X1.5m, Provided	MR
3.	Compartmentation			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	a) Basements	NA	NA	NA
	b) Upper floors	Required	Exhaust Fan Provided	MR
5.	Fire Extinguishers			
	a) Total numbers	03 Nos.	06 Nos. Provided	MR
	b) Types	ABC/CO ₂	ABC-04 & CO ₂ -02	MR
	c) IS marking	ISI marked	Provided	MR

2/

6.	First-Aid Hose Reels			
	a) Total numbers on each floor	01 Nos.	Provided	MR
	b) Length of hose reel hose	30m	Provided	MR
	c) Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	NA	NA	NA
	b) Location of Main Panel	NA	NA	NA
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	NA	NA	NA
	e) Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	a) Basement	NA	NA	NA
	b) Ground & Upper Floors	NA	NA	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	a) Size of riser/down-comer	100mm.	Provided	MR
	b) Number of hydrants per floor	01 Nos.	Provided	MR
	c) Hose Box	01 Nos.	Provided	MR
12.	Yard Hydrants			
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	Terrace level			
	➤ Discharge of pump	450LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for firefighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	Fire Control Room			
	a) Detector System Panel	NA	NA	NA
	b) Flow Switch Panel	NA	NA	NA
	c) PA System Panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were randomly checked and found functional at the time of inspection.

NOTE :- Owner/occupier has given an undertaking placed at C-8 dated 27/04/2026, that Mezzanine Floor (Storage) will be used for storage purpose only.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the Rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service rules, 2010. Accordingly, DFA is put up for approval and signatures please.

Last Date of Disposal-05/05/2026

Signature of the Inspecting Officer
Name- Sarabjeet Singh
Designation - ADO(BCP)

DO (SD)

[Signature]
30/4/26

[Signature]
4/5/26

[Signature]
4/5/26
A.K. MALIK

[Signature]
Principal Director

[Signature]
CFO to Sessue
04/05/26

[Signature]
5/5/26
A.K. MALIK
05/05/26

[Signature]
CFO (SZ)