



C22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2025/ 1129

Dated: 11/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that The Global School Academy located at L-1<sup>st</sup>, A-368, Main Bandh Road, Sangam Vihar, New Delhi-110080, was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/SZ/2022/793 dated 27.07.2022 for ground floor only. The School building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 04.09.2025 in the presence of Mr. Y.P. Aggarwal (Manager) and found that School now running at Ground + 01 upper floor of the building. The School building has complied with the fire prevention and fire safety requirements in accordance with the circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Directorate of Education and the School building (Ground + 01 upper floor) is fit for occupancy of Group B "Educational Building" (School) with effect from ..11.09.2025 renewed for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on.....11.09.2025 at New Delhi by

11/09/2025  
(Virendra Singh)

Chief Fire Officer

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISTT. South Sector-3, R.K. Puram, New Delhi-22.
2. The Principal, The Global School Academy located at L-1<sup>st</sup>, A-368, Main Bandh Road, Sangam Vihar, New Delhi-110080.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.

2/14

## INSPECTION REPORT

1	Name and address of the building:	The Global School Academy located at L-1 <sup>st</sup> , A-368, Main Bandh Road, Sangam Vihar, New Delhi-110080.		
2	Building is comprised of	Ground + 01 upper floor		
3	Type of occupancy	Group B –Educational Building (School)		
4	Type of case:	Renewal		
5	Details of previous FSC:	F6/DFS/MS/School/SZ/2022/793 dated 27.07.2022 for ground floor only		
6	Fire safety directives no.:	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of inspection:	04.09.2025		
8	Name of the inspecting officer:	Rajesh Kumar Shukla, ADO (M. Road)		
9	Name and designation of the officer from the building side:	Mr. Y.P. Aggarwal (Manager)		
10	Year of construction:	2014		
11	Reference letter no.:	Outdoor diary no. 4245 dated 28.07.2025		

S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirements as Rule 35 (6)	Provide at site	Remarks MR/NMR
1	<b>Access to Building</b>			
	A Road width	Accessible	12.5 mtrs.	MR
	B Gate width	4.5 mtrs.	4.5 mtrs	MR
	C Width of internal roads	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	A No. of staircase:			
	a) Upper floor	02 nos.	02 nos.	MR
	b) Basements	NA	NA	NA
	B Width of the staircase:			
	a) Upper floor	1 staircase of 1.5 mtrs or if main staircase width is < 1.5 mtrs an additional staircase of 0.75 mtrs width is required.	1.50 mtrs each	MR
	b) Basements	NA	NA	NA
	C Protection of exits			
	a) Fire check door	NA	NA	NA
	b) Pressurization	NA	NA	NA
	D No. of continuous staircase to terrace:	NA	NA	NA
	E Width of the corridor	1.5 mtrs	Provided	MR
	F Door size	1.0 mtrs. (for class room)	1.0 mtrs. (for class room)	MR
3	<b>Compartmentation:</b>			
	A Fire check doors	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
	A Upper floors	NA	NA	NA
	B Basements	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	A Total numbers	08 nos.	08 nos.	MR
	B Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	C ISI marking	ISI marked	Provided	MR



2/15

<b>6</b>	<b>First Aid Hose reel</b>			
	A Total no. at each floor	NA	NA	NA
	B Length of hose reel	NA	NA	NA
	C Nozzle diameter	NA	NA	NA
<b>7</b>	<b>Automatic Fire Detection and Alarm System (ADAS)</b>			
	A Type of detectors	NA	NA	NA
	B Location of main panel	NA	NA	NA
	C Location of repeater panel	NA	NA	NA
	D Alternate power source	NA	NA	NA
	E Hooter's location	NA	NA	NA
<b>8</b>	<b>MOEFA</b>	NA	NA	NA
<b>9</b>	<b>Public Address System</b>	NA	NA	NA
<b>10</b>	<b>Automatic Sprinkler System</b>			
	A Basement	NA	NA	NA
	B Upper floor	NA	NA	NA
	C Sprinklers above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants</b>			
	A Size of the riser/down comer	NA	NA	NA
	B No. Of hydrants per floor	NA	NA	NA
	C Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants</b>			
	A Total no. of hydrants	NA	NA	NA
	B Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements</b>			
	A Ground Level			
	a) Discharge of main pump	NA	NA	NA
	b) Head of main pump	NA	NA	NA
	c) Number of main pump	NA	NA	NA
	d) Discharge of jockey pump	NA	NA	NA
	e) Head of jockey pump	NA	NA	NA
	f) Discharge of standby pump	NA	NA	NA
	g) Head of standby pump	NA	NA	NA
	h) Auto starting/ manual stopping	NA	NA	NA
	B Terrace Level			
	a) Discharge of terrace pump	NA	NA	NA
	b) Head of terrace pump	NA	NA	NA
	c) Alternate power supply	NA	NA	NA
	d) Auto starting of pump	NA	NA	NA
<b>14</b>	<b>Captive Water Storage for Fire Fighting</b>			
	A Underground tank capacity	NA	NA	NA
	B Draw off connection	NA	NA	NA
	C Fire service inlet	NA	NA	NA
	D Access to tank	NA	NA	NA
	E Overhead tank capacity	NA	NA	NA
<b>15</b>	<b>Exit Signage</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lift</b>			
	A Pressurization of lift shaft	NA	NA	NA
	B Pressurization of lift lobby	NA	NA	NA
	C Communication in lift car	NA	NA	NA
	D Fireman switch	NA	NA	NA
	E Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply</b>	NA	NA	NA
<b>18</b>	<b>Refuge Area</b>			
	A location	NA	NA	NA
	B Total area	NA	NA	NA
<b>19</b>	<b>Fire Control Room</b>			
	A Fire detection system panel	NA	NA	NA
	B Flow switch panel	NA	NA	NA
	C P A system panel	NA	NA	NA
	D Battery backup	NA	NA	NA
	E Building floor plan	NA	NA	NA

W/16

The Global School Academy located at L-1<sup>st</sup>, A-368, Main Bandh Road, Sangam Vihar, New Delhi-110080.

20 Special Fire Protection for special risk if any

NA

**LEGENDS:-** Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided But Not Functional (PNF).

Note:- As per previous inspection report school is running on ground floor only of the building which comprised of Ground + 01 upper floor now the school running at Ground + 01 upper floor of the building.

The fire protection systems provided in the building were tested checked and found properly functional at the time of inspection.

If agreed to the note above & in view of the compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education circular no. 3298 to 3398 dated 01.03.2011, the FSC issued vide letter no. F6/DFS/MS/School/SZ/2022/793 dated 27.07.2022 is recommended to be renewed.

04/9/25

Signature of the Inspecting Officer

Name Rajesh Kumar Shukla

Designation ADO (M. Road)

DO (SD)

8/9/25

8/9/2025

Principal Director

CFO + Sec.

29/09/25

CFO

10/9/2025

ADO (M.R.)

File is put up for signatures ple

11/9/25

11/9/2025

MS