



d/51

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/EH/2026/NDZ/ 369

Dated: 16/04/2026



FIRE SAFETY CERTIFICATE

Certified that the r/o M/s The Golden Dragon Restaurant (Unit of Royal Orchid Caterers) running Ground Floor only located at A- 5/11, Krishna Nagar, Shahdara, Delhi-110051, comprised of ground plus three, owned/occupied The Golden Dragon, owned/occupied The Golden Dragon Restaurant was issued FSC vide letter No. F.6/DFS/MS/EH/ NDZ /2023 /343 dated 20/11/2023. The premises was re-inspected by the officer concerned of this department on dated 14/04/2026 in the presence of Mr. Pawan Kumar, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy Group 'D' "Assembly" (Restaurant at running Ground Floor) with effect from ..16/04/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on16/04/2026 at New Delhi by

16/4/26

(Dr. S. K TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

o/c R

To:-

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
2. M/s The Golden Dragon Restaurant (Unit of Royal Orchid Caterers) located at A- 5/11, Krishna Nagar, Shahdara, Delhi-110051.

MCD ID NO. 2026032503573

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : **M/s The Golden Dragon Restaurant Unit of Royal Orchid Caterers located at A- 5/11, Krishna Nagar, Shahdara, Delhi-110051**
2. Building is comprised of : Ground plus three upper floors but restaurant is running on ground floor of the building.
3. Type of Occupancy : Assembly (Eating House)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/EH/NDZ/2023/343 dated 20/11/2023
6. Fire Safety directive letter No : NBC Part IV
7. Date of Inspection : 04/04/2026
8. Name of the Inspecting officers : Nitin Lohchab, ADO (Shahd.)
9. Name and designation of Officer from the building side : Manager
10. Year of Construction : 2022
- Applicant's letter No : 2026032503573 dated 25/03/2026.

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	- Road width - Gate width - Width of internal road	06 m N/A N/A	12 m N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	- Upper floor - Basement	N/A N/A	N/A N/A	N/A N/A
	B. Width of Staircases			
	- Upper floor - Basement	N/A N/A	N/A N/A	N/A N/A
	c. Protection of Exits			
	- Fire check door - Pressurization	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.50 mtr	1.50 mtr & 1.50 mtr	MR
	g. Number of Door	02 no.	02 no.	MR
03	Compartmentation.			
	- Fire check door - Sealing of electrical shafts - Fire rating of shaft door - Water curtain - Fire dampers	Required N/A N/A N/A N/A	Provided in kitchen N/A N/A N/A N/A	MR N/A N/A N/A N/A
04	Smoke Management System.			
	- Basement - Upper floor	N/A Required	N/A Provided	N/A MR
05.	Fire Extinguishers			
	- Total numbers - Types - IS marking	04 nos. ABC /CO ₂ ISI marked	04 nos. ABC /CO ₂ ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 no.	Provided	MR
	• Hose box	01 no.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 Lpm	450 Lpm	MR
	• Head of the pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	20,000 ltrs	20,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR

N/11

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:			

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The earlier communicated shortcomings issued vide letter no. F.6/DFS/MS/EH/2026/NDZ/199 dated 05/03/2026 have been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule the FSC issued vide letter no. F.6/DFS/MS/EH/2026/NDZ/343 dated 20/11/2023, renewal under rule 35 of the Delhi Fire Service Rules 2010, is recommended for ground to third floor only.

Accordingly, DFA is put up for approval and signature please.

Last dated :- 23.04.2026

Signature of the Inspecting Officer
Name :- Nitin Lohchab
Designation :- ADO(Shah.)

DO(ED) *[Signature]* 6/4/26
Dy. CPO(NDZ) *[Signature]* 7/4/26

Principal Director *[Signature]* My CPO to Jeeva
Dy. CPO(NDZ) *[Signature]* 28/4/26
[Signature] 3/4/26

ADO(Shah.)

E.T letter is put up for your kind
please.