



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आगामी  
अग्रह महोत्सव

G-84

No. F.6/DFS/MS/GH/SZ/2026/ 59

Dated: 20/01/2026

To,

M/s The grand Orion  
A-60, Kailash Colony,  
New Delhi-110048

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s The grand Orion (A unit of Strengthening India Pvt Ltd) at A-60, Kailash Colony, New Delhi-110048.

Sir,

This has a reference to your MCD Application No. 2026010500100 dated 05/01/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 10/01/2026 in the presence of Mr. Viswajeet and observed that building comprised of Basement, Stilt, Ground Floor + 3 upper floors.

**Following shortcomings were observed during time of inspection:**

1. Fire Extinguisher provided but found empty.
2. First Aid hose reel provided but nonfunctional.
3. MOEFA Provided but not functional.
4. Automatic Sprinkler system and Internal Hydrant provided but nonfunctional.
5. Terrace Level Pump provided but not functional.
6. Exit Signage found removed at some places.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
20/01/26  
A.K. Malik  
Dy. Chief Fire Officer  
Delhi Fire Service  
O/C (L)

**Copy to: -**

The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi - 110002.