



C-32

सत्यमेव जयते

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/Banqt./NDZ/2026/ 333

Dated: 16/04/2026

To,

Sh. Avneesh Gupta
M/s The Great Palace Unit of Great Plaza and Catering Pvt. Ltd.,
Ground and Mezzanine floor of PD Area, Package 2
Seelampur Metro Station,
Delhi- 110053.

Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s The Great Palace Unit of Great Plaza and Catering Pvt. Ltd., Located at Ground and Mezzanine floor of PD Area, Package 2 Seelampur Metro Station, Delhi- 110053.

Sir,

This has reference to your MCD online application ID No. 2026032703735 dated 28/03/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 08/03/2026 in presence of Sh. Sohail Khan, Manager and observed that the shortcomings as communicated earlier vide letter No.F.6/DFS/MS/Bnqt./NDZ/2026/36 dated 12/01/2026 (copy enclosed) have not been completed yet.

In view of the above for **Fire Safety Certificate cannot be considered at this stage.** The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable action as deemed fit.

Yours faithfully


16/4/26

(Dr. S. K TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

O/C 

Copyto:-

The Commissioner, MCD, Dr. S.P. Mukherjee Civic Center, JLN marg, New Delhi – 110002.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-120431
7/5
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/Banquet/NDZ/2026/ 36

Dated: 12/01/26

To

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s The Great Palace (Unit of Great Food Plaza and Catering Pvt. Ltd.) located at Ground and Mezzanine floor of PD area, Package 2, Seelampur Metro Station, Delhi – 110053.

Sir,

With reference to the elt.mcdonline application no. 2025121315662 on the subject cited above, it is informed that the said Banquet Hall was inspected by officer concerned of this department on 01.01.2026 in the presence of Mr. Sohail Khan, Manager and it was observed that the Banquet Hall is running at Ground + Mezzanine floor of the building which is comprised of Ground + Mezzanine floor. During the inspection the following shortcomings were observed:

1. Water based fire protection systems like Fire Pumps, Hose Reels and Internal Hydrants were found non- functional.
2. Electrical cables in the Internal Hydrant shaft must be removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


12/1/26
(Dr. S. K. Tomar)

Dy. Chief Fire Officer (NDZ)

9/1 09/1/26

Copy to:-

1. The Licensee, M/s The Great Palace (Unit of Great Food Plaza and Catering Pvt. Ltd.) located at Ground and Mezzanine floor of PD area, Package 2, Seelampur Metro Station, Delhi – 110053.