

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELIII HEADQUARTERS: DELIII FIRE SERVICE: NEW DELIII- 110001



No.F6/DFS/MS/Hospital/SZ/2025/476

Dated: 22

To

The Director,

M/s The Heart Centre,

2, Ring Road, Lajpat Nagar-IV,

New Delhi-24.

Sub: Regarding issuance of Fire Safety Certificate in respect of M/s The Heart Centre located at 2, Ring Road, Lajpat Nagar-IV, New Delhi-24.

Sir,

With reference to the letter bearing outdoor diary no.5377 dated 27.08.2025 on the subject cited above, it is informed that the site was visited by officer concerned of this department on 13.09.2025 in the presence of Mrs. Shamina Khalil to check the compliance of Fire Safety guidelines issued by this department vide letter no. F6/DFS/MS/BP/2025/273 dated 07.08.2025 and it was observed that the building comprised of Basement + Stilt + Ground + Three Upper Floors. The following shortcomings were observed during the time of inspection:-

- 1. The arrangement of exit staircases is not as per issued guidelines.
- 2. The Smoke Management System is yet to be installed.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours fair fully

(Vifendra Singh)
Chief Fire Officer

Copy to:-

- The Medical Superintendent Nursing Homes, Directorate General of Health Services, 3rd floor, DGD Building, S-1, School Block, Shakarpur, New Delhi-92.
- The Executive Engineer (Bldg.) HQ: South Delhi Municipal Corporation,9th Floor, Civic Centre, Minto Road, New Delhi-110002.