



No. F6/DFS/MS/EH/NDZ/2025 / 87

Dated: 07/03/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s The Host Restaurant (A Unit of Kolmet Enterprises) located at F-8, Inner Circle, Connaught Place, New Delhi, running at Ground & Mezzanine floor of the building which is comprised of Ground + Mezzanine + 02 upper floors & was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/NDZ/2022/61 dated 09.03.2022. The building was re-inspected by officer concerned of this department on 28.02.2025 in the presence of Sh. Pankaj Gaud, Manager and found that the restaurant has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises/building (Ground & Mezzanine) is fit for occupancy of Group D "Assembly Building" (Restaurant) with effect from 07/03/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 07/03/2025 at New Delhi by

(Atul Garg)
Director
Delhi Fire Service

Reference: etl.mcdonline application no. 2025021401888.

Copy to:-

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi :-To ensure the occupancy of the building as per the issued FSC.

Conditions for the validity of Fire Safety Certificate

1. This Fire Safety Certificate is valid for restaurant at Ground & Mezzanine only.
2. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
3. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
4. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
5. The trained fire fighting staff should be available round the clock.
6. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
10. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1	Name & address of the building	M/s The Host Restaurant (A Unit of Kolmet Enterprises) located at F-8, Inner Circle, Connaught Place, New Delhi.		
2	Building is comprised of	Ground + Mezzanine + 02 upper floors (Restaurant running at Ground & Mezzanine floor of the building)		
3	Type of occupancy	Group-D, Assembly Building, (Restaurant).		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/EH/NDZ/2022/61 dated 09.03.2022		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	28.02.2025		
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)		
9	Name of the designation of officer from the building side	Sh. Pankaj Gaud, Manager		
10	Year of construction	1977		
11	Applicant's letter no.	etl.mcdonline application no. 2025021401888		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement as per Rules 35 (6)	Provided at Site	Remarks MR/ NMR
1	Access To Building:			
A	Road width	6.0 mtrs	6.0 mtrs	MR
B	Gate width	NA	NA	NA
C	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	02 nos.	02 nos.	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	1.25 mtrs & 0.75 mtrs	1.25 mtrs & 0.75 mtrs	MR
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	NA	NA	NA
E	Width of corridor	NA	NA	NA
F	Door size (exits)	1.5 mtrs (02 nos.)	Provided	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	Smoke Management System:			
A	Basement	NA	NA	NA
B	Upper floor	Mechanical/ Natural	Exhaust fans	MR

5.	Fire Extinguisher:			
A	Total numbers	05 nos.	06 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI marked	ISI marked	MR
6	First-Aid-Hose Reels:			
A	Total numbers of each floor	01 no.	01 no.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection And Alarming System:			
A	Type of detectors	NA	Smoke	NA
B	Location of main panel	NA	Provided	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	Provided	NA
8	MOEFA:	Required	Provided	MR
9	Public Address System:	NA	NA	NA
10	Automatic Sprinkler System:			
A	Basement	NA	NA	NA
B	Upper floor	Required	Provided	MR
C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
A	size of riser/down-comer	NA	NA	NA
B	Number of hydrants per floor	NA	NA	NA
C	Hose box at each floor	NA	NA	NA
12	Yard Hydrants:			
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13	Pumping Arrangements:			
A	Ground level			
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
i)	Pump house access	NA	NA	NA
B	Terrace level			
a)	Discharge of pump	900 LPM	Provided	MR
b)	Head of the pump	40 mtrs.	Provided	MR
c)	Power supply	Required	Provided	MR
d)	Auto starting of pump	Required	Provided	MR

M/s The Host Restaurant (A Unit of Kolmet Enterprises) located at F-8, Inner Circle, Connaught Place, New Delhi.

14	Captive Water Storage For Fire Fighting:			
	A	Underground tank capacity	NA	NA
	B	Draw-off connection	NA	NA
	C	Fire service inlet	NA	NA
	D	Access to tank	NA	NA
	E	Overhead tank capacity	10,000 ltrs	Provided ✓ MR
15	Exit Signage:		Required	Provided MR
16	Provision of Lifts:			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:		Required	Provided MR
18	Refuge Area:			
	A	Total area	NA	NA
	B	Location	NA	NA
19	Fire Control Room :			
	A	Detector system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	Pa system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plans	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2022/61 dated 09.03.2022 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

DO (80)

FD
3/4/25

Dy. C.F.O. (M. Road)

Kirp
04/03/25

C.F.O.

Director

Director (M. Road)

FR is put up ple

m

Uplander