



No. F6/DFS/MS/NDZ/2025/ 421

Dated 26/08/2025

To,

The Authorized Signatory,
M/s The Lawyer's Co - Operative Group Housing Society Limited,
Plot No.6, Mayur Vihar Phase -1, Delhi - 110091.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s The Lawyer's Co - Operative Group Housing Society Limited located at Plot No.6, Mayur Vihar Phase -1, Delhi - 110091.

Sir,

This has a reference to your outdoor diary no. 4141 dated 25/07/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 13/08/2025 in the presence of Mr. Sunil Kumar (President) and observed that building comprised of 04 block (B + G + 07 upper floors) & 07 blocks (G+05 upper floors).


Following shortcomings were observed during time of inspection:

1. First Aid Hose reel provided but found not functional.
2. MOEFA Provided but found not functional.
3. PA system provided but not found not functional.
4. Internal hydrant system provided but found not functional.
5. Pump are not on auto mode.
6. Exit Signage and floor signage found removed.

In view of above shortcomings, **the application for issuance for Fire Safety Certificate is rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


22/8/2025

VIRENDRA SINGH
CHIEF FIRE OFFICER
D/C DELHI FIRE SERVICE


Copy to: -

1. The Executive Engineer (Bldg.), Municipal Corporation of Delhi, Plot No. 419, Patparganj Industrial Area, Delhi -110092.