



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-187

No: F.6/DFS/MS/Banq./2026/WZ/ 272

Dated: 01/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s The Maidens Crown Banquet (A Unit of SAI Hospitality), located at Plot No. B-1, Udyog Nagar Industrial Area, New Delhi.

Sir,

This has reference to your online application received through MCD portal vide ID- 2026022702181 dated 27/02/2026 on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by the officers concerned of this department on 17/03/2026 in presence of Sh. Romil. Following shortcoming were observed at the time of inspection.

1. Fire check door found removed at some places and some fire check doors needs to be repaired.
2. Detectors found removed at some places.
3. Automatic sprinkler system found provided but not functional.
4. One main pump of 2280 lpm discharge capacity found removed.
5. Exit signage's found removed at some places.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(S.K. Dua)

Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy to:-

1. MCD Portal ID No. 2026022702181.