

c/132

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/WZ/Bnqt/2025/ 45

Dated: 13/03/2025

To,

Mr. Tushar Malhotra,  
House No.17, 3<sup>rd</sup> floor,  
62, West Punjabi Bagh,  
New Delhi-110026.

**Sub:** Renewal of FSC in r/o The Meraki Grand, located at Shop No.A-29, G. T. Karnal Road, Industrial Area, Delhi-110033.

Sir,

This is reference to online application no. 2025021301817 dated 13.02.2025 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **25.02.2025**, in presence of **Mr. Tushar Malhotra (Owner)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace fire pumps was not found in auto mode.
2. Down comer line found leakaged at terrace level .
3. FCD found removed at some places.
4. Ventilation found removed at upper floors & basement.
5. Building plan not matching with approved building plans.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

  
(Atul Garg)  
DIRECTOR  
Ph: 011-23414000  
OK  
OK

Copy To:-

1. MCD Portal Id- 2025021301817 dated 13.02.2025.