



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 33

Dated: 15/01/2025

To,

The Principal,

The Mother Marry Public School,

292-B, Main Road Mandawali, Delhi-110092.

**Subject: - Regarding grant of Fire Safety Certificate in r/o The Mother Marry Public School at  
292-B, Main Road Mandawali, Delhi-110092.**

Sir,

This has a reference to your outdoor diary no. 10365 dated 16/12/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 08/01/2025 in the presence of Mr. Gaurav Verma (Manager) and observed that building comprised of ground plus four upper floors.

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel at each floors provided but not functional.
2. Fire pump of 900 LPM provided but not functional
3. Over head water storage tank of capacity 15,000 liters provided against required capacity of 25,000 liters.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

**Copy to:-**

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.