

c/28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 143

Dated:- 01/04/2025

To,

The Manager,  
M/s The Orion Elite ( A Unit of Strengthening India Pvt. Ltd),  
H-3, Green Park Extension, New Delhi-110016.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S The Orion Elite ( A Unit of Strengthening India Pvt. Ltd), H-3, Green Park Extension, New Delhi-110016.**

Sir,

This has reference to on line ID No. 2025031103276 dated 11.03.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 22/03/2025 in the presence of Manager and following shortcomings were observed: -

1. Smoke management system is not provided in basement.
2. 02 staircase of 1.5 meter is not provided in the basement.
3. Width of corridor of 1.80 m is not provided.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg )  
DIRECTOR  
01123414000