



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/WZ/2026/ 329

Dated: 16 /04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s The Post Office (A Unit of Shine Hospitalities) Located at Shop no. F 83, Vishal Enclave, Rajouri Garden, New Delhi- 110027.

Sir,

This has a reference to MCD application No. 2026031302865 dated 24/03/2026, on the subject cited above. In this connection, this is to inform you that the above-mentioned premises was visited by the officer concerned of this department on dated 03/04/2026 in the presence of Mr. Rohit Mehra (Staff) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. First-Aid-Hose Reel provided but not functional.
2. MOEFA not provided in common area.
3. Internal hydrant provided but not functional.
4. Terrace fire pump of capacity 450 LPM found removed.
5. Exit & floors Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


13/04/26
(S. K. Dua)

Chief Fire Officer
Delhi Fire Service

Copy to :

1. The Dy. Health Officer, MCD, West Zone, Vihar Enclave, Rajouri Garden, New Delhi-110027.
(dhowest zone@gmail.com)