



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 356

Dated: 23/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s The Sahib Guest House, 7779/XV, Ram Nagar, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026032503536 dated 25/03/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 04/04/2026 in the presence of Sh. Jasvinder, Owner and following shortcomings were observed: -

1. Smoke Management System found removed.
2. The fire extinguishers installed at site found outdated.
3. CO detectors provided but found non-functional.
4. Manually Operated Electronic Fire Alarm (MOEFA) provided but found non-functional.
5. Public Address System provided but found non-functional.
6. Automatic operation of Fire Pump found removed.
7. Domestic connection provided in Overhead water storage tank is not permitted.
8. Lift signage found removed at some places.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


22/4/26
(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Manager, M/s The Sahib Guest House, 7779/XV, Ram Nagar, Paharganj, New Delhi - 110055.