



No: F.6/DFS/MS/School/2025/WZ/ 359

To,

The Manager, The Sarthi School, Kh. No. 31/19, Village Harewali, Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o The Sarthi School located at Kh. No. 31/19, Village Harewali, Delhi- 110039. Sir,

This has reference to your e mail id dated 12.08.2025 and letter no. nil received through outdoor diary no. 4965 dated 18/08/2025 on the subject cited above. In this connection, it is to inform you that above said school building was visited by the officer concerned of this department on 18/09/2025 to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/School/2025/WZ/310 dated 01/05/2025. Sh. Lalit Kumar Gupta was present at the time of inspection. During the course of inspection it was observed that shortcomings communicated via above mentioned letter were not rectified yet.

In view of the above, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Virendra Singh)

Chief Fire Officer

Enclosed as above:-

Copy to:-

1. Director of Education, Govt. of NCT Delhi, Old Secretariat, New Delhi.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

clo4

No: F.6/DFS/MS/School/2025/WZ/ 3lo

Dated: 01/05/202

To,

The Manager, The Sarthi School, Kh. No. 31/19, Village Harewali, Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o The Sarthi School located at Kh. No. 31/19, Village Harewali, Delhi- 110039.

This has reference to your application no. Nil received through outdoor diary no. 14348 dated 11.03.2025 on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by officer concerned of this department on 15.04.2025 to ascertain the availability and operability of the fire prevention and fire safety measure, Sh. Lalit Kumar Gupta was present at the time of inspection. During the course of visit it was observed that building is comprised of Two Blocks (Block 1- Ground plus first floor & Block 2- Ground floor only). Block-1 is used as office and residential purpose and school is running in Block-2.

Your request for issuance of FSC is rejected due to the following shortcoming:-

1. Gate width found 3 m against the required width of 4.5 m.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

Ph. 011-23414000

olla m

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.