



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/264

Dated: 22/04/2025

To,

The Principal,
The Saviour's School,
B-106 (New No.872),
New Ashok Nagar,
Delhi – 110096

**Subject: - Regarding grant of Fire Safety Certificate in r/o The Saviour's School located at B - 106
(New No.872), New Ashok Nagar, Delhi – 110096.**

Sir,

This has a reference to your Outdoor Dairy No. 14939 dated 25/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 15/04/2025 in the presence of Mrs. Valsamma Thomas (Associate Director) and observed that building comprised of basement (Store) + ground + three upper floors **Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel provided but not functional.
2. Fire pump of 450 LPM provided but not functional.
3. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, Delhi Municipal Corporation, 419, Udyog Sadan, Patparganj Industrial Area, Delhi – 110092.