



No. F6/DFS/MS/School/NDZ/2025/ 617

Dated: 07/08/2025

To,

The Principal,
The Saviour's School,
B - 106 (New No.872),
New Ashok Nagar,
Delhi - 110096

Subject: - Regarding grant of Fire Safety Certificate in r/o The Saviour's School located at B - 106 (New No.872), New Ashok Nagar, Delhi - 110096.

Sir,


This has a reference to your email dated 04/07/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 21/07/2025 in the presence of Mrs. Valsamma Thomas (Associate Director) and observed that building comprised of Basement (Store), Ground plus three upper floors, Terrace floor - 03 room (SPS).

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel provided but not functional.
2. Fire pump of 450 LPM provided but not functional.
3. Hose box found removed on first and third floor.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, Delhi Municipal Corporation, 419, Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.