



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/Bnqt./2025/NDZ/ 19

Dated: 03/04/2025

FIRE SAFETY CERTIFICATE

Certified that The Savour Banquet Hall located at 662/10, old C-2 Shivpuri Main Road, Krishna Nagar Extn, Delhi-110051 is running at ground floor of the building comprised of basement, stilt, ground plus three upper floors owned/occupied by The Savour Banquet Hall was pervious FSC issued vide letter no. F.6/DFS/MS/BNQT/2022/NDZ/46 dated 16/08/2022 for ground floor only. The premise was inspected by the officer concerned of this department on 22/03/2025 in the presence of Mr. Mr. Puneet Wadhawa found that the premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class "Assembly, Group-D" (Ground floor only) with effect from 03/04/2025 and valid up to 31/03/2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....03/04/2025.....at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To:-

1. The Joint. Commissioner (Lic.)
1st floor Police Station Defence Colony, New Delhi
MCD ID No. 2025030803108 dated 08/03/2025

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The basement shall be used as per the provisions of BBL/NBC Part-IV & presently being used for storage.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

2/40

1. Name & address of the building : The Savour Banquet Hall located at 662/10, old C-2 Shivpuri Main Road, Krishana Nagar Extn, Delhi-51
2. Building is comprised of : Basement + stilt+ 03 upper floors
(Banquet Hall running at ground floor only)
3. Type of Occupancy : Assembly (Group-D)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/BNQT/2022/NDZ/46 dt 16/08/2022
6. Fire Safety directive letter No : NBC Part IV
7. Date of Inspection : 22/03/2025
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Puneet Wadhawa
10. Applicant's letter No : 2025030803108 dated 08/03/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part IV Requirements	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	06 mtr	30 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	01 no.	03 no.	MR
	• Basement	02 nos.	02 nos.	MR
	B. Width of Staircases			
	• Upper Floor	1.50 mtr	02 mtr, 1.25 mtr & 01 mtr	MR (accepted earlier)
	• Basement	1.50 mtr	1.25 mtr & 0.80 mtr	MR (accepted earlier)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 nos.	01nos.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr	Provided	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	12 a/c per hour	Exhaust	MR
	• Upper floor	12 a/c per hour	Ventilated	MR
05.	Fire Extinguishers.			
	• Total numbers	08 nos.	Provided	MR
	• types	ABC/CO ₂	ABC/CO ₂	MR
	• IS marking	Required	Provided	MR

2 X

2/41

06	First-aid-Hose Reels.			
	Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	Smoke	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose Box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 Lpm.	450 Lpm.x 02 nos.	MR
	➤ Head of the Pump	30mtr.	30mtr.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000ltrs.	20,000ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

N/42

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule. The FSC issued vide letter No. F6/DFS/MS/BNQT/2022/ NDZ/46 dated 16/08/2022 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.


 Signature of the Inspecting Officer
 Name : Deepak Kumar
 Designation : ADO (Shd)


DO(ED)


 24/03/2025

Dy C.F.O. (NDZ)


 24/03/25

C.F.O.



 27/3/2025

Director



Sir, F.T. letter is put up for your

kind signature pl.


 02/04/2025

Director

m

uploaded
 04/04/25