



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2025/ 182

Dated: 01/04/2025

To

The Principal,
The Scholar School,
E-11, Abul Fazal Enclave, Okhla,
Jamai Nagar, New Delhi-25.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **The Scholar School** located at **E-11, Abul Fazal Enclave, Okhla, Jamai Nagar, New Delhi-25.**

Sir,

With reference to the letter bearing outdoor diary no. 14700 dated 19.03.2025 on the subject cited above, it is informed that the school building was inspected by officer concerned of this department on 21.03.2025 in the presence of administrator and following shortcoming was observed.

1. Basement shall be provided with an alternate staircase of 1.50 meters width.
2. Two Hose reels shall be additionally provided at each floor level.
3. Corridor in Admin. lock shall not be terminate into dead end at upper floors.
4. Multipurpose Hall shall have a dedicated Hose reel.
5. Sprinkler systems shall be provided in the basement.
6. An additional terrace fire pump of 450 LPM shall be provided alongwith auto start mechanism.
7. 15,000 liters terrace tank shall be provided.
8. Exit signages shall be provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.