

C/44

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/SZ/2025/133

Dated: 25/03/2025

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding issuance of Fire Safety Certificate in respect of **M/s The Venue located at K-17, Kh. No. 725, Old Rangpuri Road, Mahipalpur, Delhi.**

Sir,

This has reference to online application I.D. No. 2025030602898 dated 06.03.2025 on the subject cited above. In this connection, it is to inform you that the building/ premises was visited by the officer concerned of this department on 18.03.2025 in the presence Mr. Vikas and observed that the building is comprised of basement + ground + 05 upper floors and have complied the shortcomings issued vide letter no. F.6/DFS/MS/GH/2025/SZ/69 dated 07.02.2025 except following which still exists.

1. Smoke ventilation system provided but found not working.
2. First aid hose reel provided but found non functional.
3. Carbon Monoxide detector provided but found not working.
4. Overhead tank capacity 4,000 ltrs provided against the required capacity 15,000 ltrs.
5. The occupancy above 3rd floor is not allowed as per clause 7.31 of UBBL 2016.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director ok

Delhi Fire Service
Tel: 011-23414000

Copy to:-

The Manager,

M/s The Venue at K-17, Kh. No. 725, Old Rangpuri Road, Mahipalpur, Delhi.

C 84 213