

C/42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/DMRC/NDZ/2025/ 416

Dated: 08 / 08 / 2025

FIRE SAFETY CERTIFICATE

Certified that the **Tis Hazari Metro Station, Line-1(Excluding PD area), Delhi**, comprised of **Ground + Concourse + Platform area** was earlier granted FSC by this department vide letter No. F6/DFS/MS/DMRC/NDZ/2022/386 dated 02.09.2022. Now, the premise was re-inspected by the officer concerned of this department on 30.07.2025 in the presence of Mr. Saiyam Jain (Manager/ Fire) and found that the building have deemed complied with the prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy class **(Group D-7) "Assembly Building", (Excluding PD Area)** with effect from 08/08/2025 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules 2010, printed below.

Issued on 08/08/2025 at New Delhi by.


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
01/08/25

Copy to:-

1. Mr. Rajesh Aggarwal, GM/E&M, DMRC Ltd., Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-01.

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT						
1	Name & address of the building		M/s Tis Hazari Metro Station, Line-1, (Excluding PD area) Delhi .			
2	Building is comprised of		(Ground + Concourse + Platform)			
3	Type of occupancy		(Group-D) Assembly Building			
4	Type of case		Renewal			
5	Details of Previous FSC		F6/DFS/MS/DMRC/NDZ/2022/386 dated 02.09.2022			
6	Fire Safety direction letter no.		NA			
7	Date of inspection		30.07.2025			
8	Name of the inspecting officers		ADO(SPM)			
9	Name of the designation of officer from the building side		Mr. Saiyam Jain (Manager/Fire)			
10	Year of construction		2005			
11	Applicant's letter no.		Letter no. DMRC/O&M/FIRE/NOC/Line-1/2025/06/40 dated 26.06.2025			
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33		Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/NM R	
1	Access to building					
	A	Road width	06 mtr.	12 mtr.	MR	
	B	Gate width	NA	NA	NA	
	C	Width of internal road	6 mtr.	6 mtr.	MR	
2	Number, Width, Type and Arrangement of Exits					
	A	Number of staircases				
		a	Upper floor	02 nos.	06 nos.	MR
		b	Basement	N/A	N/A	N/A
	B	Width of staircases				
		a	Upper floor	Required	02 nos. ground to concourse-2.75 m each, 06 nos. concourse to platform-(03 nos. 2.75 m each, 02 nos. 2.70 m each & 01 no. 2.60 m, 04 nos. emergency s/c- 1.70 m each platform to ground floor.	MR
		b	Basement	N/A	N/A	N/A
	C	Protection of exits				
		a	Fire check door	N/A	N/A	N/A
		b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace		04 nos.	04 nos.	MR
	E	Width of corridor		N/A	N/A	N/A
	F	Door size		N/A	N/A	N/A
3	Compartmentation					
	A	Fire check door		N/A	N/A	N/A
	B	Sealing of electrical shafts		N/A	N/A	N/A
	C	Fire rating of shaft door		N/A	N/A	N/A
	D	Water curtain		N/A	N/A	N/A
	E	Fire dampers		N/A	N/A	N/A
4	Smoke Management System.					
	A	Basement		NA	N/A	N/A
	B	Upper floor		12 ACPH	Provided	MR

5.	Fire Extinguisher				
	A	Total numbers	30 nos.	30 nos.	MR
	B	Types	ABC & Co2	Provided	MR
	C	ISI marking	Required	Provided	MR
6	First-Aid-Hose Reels.				
	A	Total numbers of each floor	03 nos.	03 nos.	MR
	B	Length of hose reel hose	30 mtrs.	Provided	MR
	C	Nozzle diameter	05 mm	Provided	MR
7	Automatic Fire Detection And Alarming System.				
	A	Type of detectors (Smoke & Heat)	Required	Provided	MR
	B	Location of main panel	Required	Provided at station control room	MR
	C	Location of repeater panel	Required	Provided at fire control room	MR
	D	Alternate source of power	Required	Provided	MR
	E	Hooter's Location	Required	Provided	MR
8	MOEFA		Required	Provided	MR
9	Public Address System		Required	Provided	MR
10	Automatic Sprinkler System				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants				
	A	size of riser/down-comer	100 mm	100 mm	MR
	B	Number of hydrants per floor	03 nos.	03 nos.	MR
	C	Hose box	03 nos.	03 nos.	MR
12	Yard Hydrants.				
	A	Total number of hydrants	04 nos.	04 nos.	MR
	B	Hose box	04 nos.	04 nos.	MR
13	Pumping Arrangements.				
	A	Ground Level			
	a	Discharge of main Pump	2280 LPM	2280 LPM	MR
	b	Head of Main Pump	70 m	70 m	MR
	c	Number of main pumps	02 nos.	02 nos.	MR
	d	Jockey pump out put	216 LPM	216 LPM	MR
	e	Jockey pump head	70 m	70 m	MR
	f	Standby pump out put	2280 LPM	2280 LPM	MR
	g	Standby pump Head	70 m	70 m	MR
	h	Auto Starting /Manual stopping	Required	Provided	MR
	i	Pump house access	Required	Provided	MR
	B	Terrace Level			
	a	Discharge of pump	N/A	N/A	N/A
	b	Head of the Pump	N/A	N/A	N/A
	c	Power supply	N/A	N/A	N/A
	d	Auto starting of pump	N/A	N/A	N/A

14	Captive Water Storage for Fire Fighting.				
	A	Underground tank capacity	1,00,000 ltrs.	Provided	MR
	B	Draw-off connection	Required	Provided	MR
	C	Fire service inlet	Required	Provided	MR
	D	Access to tank	Required	Provided	MR
	E	Overhead tank capacity	20,000 ltrs.	Provided	MR
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	A	Pressurization of lift shaft	N/A	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A	N/A
	C	Communication in lift car	Required	Provided	MR
	D	Firemen's grounding switch	Required	Provided	MR
	E	Lift signage	Required	Provided	MR
17	Standby Power Supply		Required	Provided	MR
18	Refuge Area.				
	A	Total area	N/A	N/A	N/A
	B	Location	N/A	N/A	N/A
19	Fire Control Room				
	A	Detector system panel	Required	Provided	MR
	B	Flow switch panel	Required	Provided	MR
	C	PA system panel	Required	Provided	MR
	D	Battery backup	Required	Provided	MR
	E	Building floor plans	Required	Provided	MR
20	Special Fire Protection Systems For Protection Of Special Risks, If Any: HT, LT and Elect. Panel protected with Co2 gas based flooding system.		Required	Provided	MR

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, FSC issued vide letter no. F6/DFS/MS/DMRC/NDZ/2022/386 dated 02.09.2022 is recommended to be renewed (excluding P.D. area) under Rule 35 of the Delhi Fire Service Rules 2010.

Sumit Kumar
30/07/2025

Signature of the Inspecting Officer

Name Sumit Kumar

Designation ADO (SPM)

DO (CD)

[Signature]
30/7/25

[Signature]
Dy. C.F.O. (NDZ)

[Signature]
31/07/25

[Signature]
C.F.O.

[Signature]
u/o P.D. area

[Signature]
Principal Director

[Signature]
C.F.O. to Secy.