

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



No F 6/DFS/MS/2025/School/WZ/ 1294

Dated: 06 / 11 /2025

FIRE SAFETY CERTIFICATE

Issued on 06 11 2025 at New Delhi

(S. K. Dua)

Dv. Chief Fire Officer (WZ)

Delhi Fire Service

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.

2. The Principal, Rose Merry Public School, MD Block, Pitampura, Delhi-110034. (School ID-1411196).

Conditions for the validity of Fire Safety Certificate:

- 1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3. The trained fire fighting staff should be available round the clock.
- 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
- 8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+ard+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

NRI

- 3			DICDEC	TION DEPORT				
				TION REPORT				
1.	Name & ad	dress of the building	(School	ID-1411196).	l, MD Block, Pitampur	a, Delhi-110034.		
2.	Type of Occupancy		Educational					
3.	Type of Case Details of Previous NOC		Renewal (Ground + 01 upper floor) F.6/DFS/MS/School/WZ/2022/953 dated 05.09.2022.					
4								
5.	Fire Safety	directives letter No		298-3398 dated 01.	.03.2011.			
6.	Date of ins	pection	24.10.2		100 W. 1 000			
7.	Name of Inspecting Officer		Sh. Ajay Kumar Sharma ADO (Wazirpur/MN)					
	From the b	designation of officers uilding side	1.0	amlesh Amar (Man				
9.	Year of Co	nstruction	1.00		Report dated 04.05.2018	& 16.08.2022)		
10	. Applicant's	letter No.	produced in the local	.7073 dated 14.10.2		TE .		
S.		Standards on fire prev	ention	DOE	Provided at site	Remarks MR/NMR		
No		fety U/R 33	1	Requirement		MINIMIN		
1.	Access to	ouilding						
	Road width			Accessible	5m	MR		
	Gate width			Accessible	338cm	MR		
	Width of internal road		5.7	-NA-	-NA-	-NA-		
2.	Number,	Width, Type & Arrange	ment of	Exits				
	a. Number of staircases							
		Upper Floors		02nos.	02nos.	MR		
		Basements		-NA-	-NA-	-NA-		
	b. Width	The state of the s						
	READ OCCUMENCATIONS	• Upper Floor		1.5m	1.18m & 0.75m	MR(Old case)		
				-NA-	-NA-	-NA-		
		Basements		-NA-	31121	112.		
		Protection of exits		-NA-	-NA-	-NA-		
		Fire check door		-NA-	-NA- '	-NA-		
	•	Pressurization						
		continuous staircases to terrace		01nos. 1.5m	Provided	MR		
		of Corridor			1.90m	MR		
	f. Door S			1m	0.82m	MR(Old case)		
3.	Compartmentation			NT A	214			
	a) Fire check door			-NA-	-NA-	-NA-		
	b) Sealing of electrical shafts			-NA-	-NA-	-NA-		
	c) Fire Rating of shaft door		-NA-	-NA-	-NA-			
	d) Water Curtain		-NA-	-NA-	-NA-			
	e) Fire Dampers			-NA-	-NA-	-NA-		
4.	Smoke Management System a) Basements			-NA-	NYA			
	360			-NA-	-NA-	-NA-		
		per floors		-NA-	-NA-	-NA-		
5.	Fire Extin			05nos.	P			
	a) Total numbers			ABC/CO2	Provided	MR		
	b) Types c) IS marking		ISI marked	ABC/CO2	MR			
				тот шагкед	Yes	MR		
6.		Hose Reels tal numbers on each floor	T	-NA-				
	a) Total numbers on each floor b) Length of hose reel hose		į.	-NA-	Provided	-N.A-		
	c) Nozzle diameter		-NA-	Provided	-NA-			
	c) No	c fire detection and alar	ming syst		Provided	-NA-		
7.	Automatic	c in c detection and alar	ming syst	O.,				

Chy

MILL

	a) T	1.87				
	a) Type of detectors b) Locari	-NA-	-NA-	-NA-		
		-NA-	-NA-	-NA-		
	c) Location of Main Panel d) Alternate source of	-NA-	-NA-	-NA-		
8.		-NA-	-NA-	-NA-		
9.	e) Hooters' Location	-NA-	E-MHOW)	-NA-		
10.	Public	-NA-		-NA-		
	Automatic Sprinkler System a) Basement	-NA-		-NA-		
	a) Basement	-NA-	-144-	2 1125		
	O) Grow	-NA-	NA.	-NA-		
11.	c) Sprinkler above false ceiling Internal Hydrants	-NA-	S 6800	-NA-		
	Internal Hydrants a) Size of the size of	-NA-	15 (84)/5	-NA-		
	4) 11	MA-	-NA-	-INA-		
	b) Number of hydrants per floor C) Hose Box	-NA-		T 374		
12.	Yard IV	-NA-	27,000,00	-NA-		
	" IIVana	-NA-	19 (2007)	-NA-		
	LOtol Lotol	130	-NA-	-NA-		
13.	b) Hose Box	-NA-	37.			
Ü	mping Arrangem	-NA-		-NA-		
	• Ground Level		-NA	-NA-		
	Dischar					
	➤ Head of Main pump Number of	-NA-	NIA			
	Number of main pumps Jockey Pump	-NA-		-NA-		
	Jockey Pump out put	-NA-		-NA-		
	Jockey pump head	-NA-		-NA-		
		-NA-	F108230	-NA-		
		-NA-		-NA-		
		-NA-	E.	-NA-		
	. Subc Access	-NA-		-NA-		
	Terrace level	-NA-		-NA-		
	Discharge of pump		11/13-	-NA-		
	> Head of the pump	-NA-	450lpm			
	> Power Supply	-NA-		-NA-		
	Auto Starting of	-NA-	2723/2/2011	-NA-		
14.	Captive Water Storage for fire fighting	-NA-		-NA-		
	• Undergraved and live lighting			-NA-		
	Charground tank capacity	-NA-	NA	1		
	Draw-off connection	-NA-		-NA-		
	Fire service inlet	-NA-		-NA-		
	> Access to tank		A STATE OF THE PARTY OF THE PAR	-NA-		
	NO CONTRACTOR OF THE PARTY OF T	00.07%	-NA-	-NA-		
1.5	Overhead Tank capacity First Signage	-NA-	2000ltr	-NA-		
15.	Exit Signage.	Required	Provided	MR		
16.	Provision of Lifts.					
	a) Pressurization of Lift Shaft	-NA-	-NA	-NA-		
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-		
	c) Communication In lift Car	-NA-	-NA-	-NA-		
	- Counding Switch	-NA-	-NA-	-NA-		
		-NA-		-NA-		
	e) Lift Signage	-NA-		-NA-		
17.	Standby power supply	- Automobile	(100 PM,2055)			
18.	Refuge Area.					

a) Total Area	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
b) Location Fire Control Room	1		
a) Detector System Panel	-NA-	-NA-	-NA-
b) Flow Switch Panel	-NA-	-NA-	-NA-
c) PA System Panel	-NA-	-NA-	-NA-
d) Battery backup	-NA-	-NA-	-NA-
e) Building Floor Plans	-NA-	-NA-	-NA-
Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2022/953 dated 05.09.2022 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer Name Ajay Kumar Sharma Designation ADO(Wazirpur/MN)

DO(W) 128/10

Dy Go wi

Principal Director

Dy. Cro ho

2 1000

Dy. CFO (WZ)

F.T. please

03/11

ADO(WP)

for letter to port up for kend perisal & Sign. Pearse.

4/4/4/24

Defo (pr)

ving

8/11/25