

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2025/SZ/ 361

Dated: 01/08 /2025

To,

The Officiating Director / GM (Trg.)
Indian Aviation Academy,
Vasant Kunj, New Delhi 110070.

Sub: Regarding renewal of Fire Safety Certificate in r/o Training Centre and Auditorium of Indian Aviation Academy, Vasant Kunj, New Delhi.


Sir,

This was reference to your letter IAA/Engg.(E)Fire/NOC-Renewal/2025-26/201 dated 26/06/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.07.2025 in the presence of Ms. Himanshi (Sr. Manager/EE) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. The Self closing device in Fire Check Door found removed at some locations in basement lift lobbies/Staircase.
2. There are opening at Electrical shaft due to repair works which needs to be sealed in basement and upper floors.
3. Smoke management system not on auto mode.
4. DG pumps not on auto mode.
5. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


31/7/2025

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:

1. The Executive Engg. (Bldg.), MCD, Central Zone, Jal Vihar, Lajpat Nagar, New Delhi 110024