



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No: F.6/DFS/MS/School/2025/WZ/ 343

Dated: 06/05/2025

To,

The Principal,  
Tri Nagar Public School,  
260/21, Onkar Nagar-B, Tri Nagar,  
Delhi-110035.

Sub: - Regarding Issuance of Fire Safety Certificate in r/o Tri Nagar Public School located at 260/21, Onkar Nagar-B, Tri Nagar, Delhi- 110035.

Sir,

This has reference to your application no. MSD/PC/2025/321 dated 15/04/2025 received through outdoor diary no. 646 dated 16.04.2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 01.05.2025 to see the compliance of requisite fire safety measures. Smt. Savita Sharma was present at the time of inspection.

During the course of inspection it was observed that the school is running on Ground floor to 2<sup>nd</sup> floor in a building comprised of Ground plus three upper floors. Following shortcomings were observed at the time of inspection:-

1. Alternate staircase which was reaching up to 2<sup>nd</sup> floor found removed..
2. First aid hose reel found provided but not functional.
3. Terrace level pumps found removed.
4. Overhead tank of 2000 ltrs capacity found provided against the requirement of 5000 ltrs.
5. Exit signages found removed.
6. Electric meter installed near the staircase has to be removed to a safer location.
7. Form J & K not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.