



No. F6/DFS/MS/EH/SZ/2026/ 54

Dated: 20/01/2026

FIRE SAFETY CERTIFICATE

Certified M/s Tripti Restaurant and Catering Services at A-67/1, Mahipalpur, National Highway-8, New Delhi comprised of Basement, Ground plus two upper floors but restaurant running at ground floor only owner occupied by Mr. Anil Kumar Jain was issued earlier Fire Safety Certification vide letter No. F6/DFS/MS/EH/2022/SZ/351 dated 16/12/2022. The premises was re-inspected by the officer concerned of this department on 07/01/2026 in presence of Mr. Rajesh Khanna (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in the accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Assembly Building Group 'D' (Restaurant is running at ground floor only)**" with effect from 20/01/2026 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 20/01/2026 at New Delhi by.


A.K. Malik
Dy. Chief Fire Officer
Delhi Fire Service
o/c (W)

Copy to: -

1. The Dy. Health Officer, Public Health Department, Green Park Zone, New Delhi 110016 (Ref. MCD Portal application No. 2025121715839 dated 01/01/2026)

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

01.	Name & address of the building	M/s Tripti Restaurant and Catering Services at A-67/1, Mahipalpur, National Highway-8, New Delhi		
02.	Building is comprised of	Basement, Ground, plus two upper floors but restaurant running at ground floor only		
03.	Type of occupancy	Assembly Building (Restaurant) Group 'D'		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/EH/SZ/2022/SZ/351 dated 16/12/2022		
06.	Fire safety directives letter no.	Nil		
07.	Date of inspection	07.01.2026		
08.	Name of the inspecting officers	Yashwant Singh Meena, A.D.O/BCP		
09.	Name of the designation of officer from the building side	Mr. Rajesh Khanna (Manager)		
10.	Year of construction	2000		
11.	Applicant's letter no.	MCD Portal application No. 2025121715839 dated 01/01/2026.		

S.No	Minimum standard of fire prevention and fire safety U/R 33	UBBL - 2016 Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
	A Road width	Required	10 m	MR
	B Gate width	-NA-	-NA-	-NA-
	C Width of internal road	-NA-	-NA-	-NA-
02.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	-NA-	-NA-	-NA-
	C Basement	-NA-	-NA-	-NA-
	B Width of staircases			
	a Upper floor	-NA-	-NA-	-NA-
	C Basement	-NA-	-NA-	-NA-
	C Protection of exits			
	a Fire check door	-NA-	-NA-	-NA-
	b Pressurization	-NA-	-NA-	-NA-
	D No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	E Width of corridor	-NA-	-NA-	-NA-
	F Door size	Old case	02 Exits of 1.10m	MR (old case)
03.	Compartmentation:			
	A Fire check door	Required	Provided	MR
	B Sealing of electrical shafts	Required	Provided	MR
	C Fire rating of shaft door	-NA-	-NA-	-NA-
	D Water curtain	-NA-	-NA-	-NA-
	E Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
	A Basement	N/A	-NA-	-NA-
	B Upper floor	12 ACPH	Exhaust Fan Provided	MR
05.	Fire Extinguishers			
	A Total numbers	08 Nos.	12 Nos.	MR
	B Types	ABC & CO2	ABC-04 & CO2-02	MR
	C ISI marking	ISI Marked	Provided	MR
06.	First-Aid-Hose Reel:			
	A Total numbers of each floor	Hose Reels	Provided near restaurant	MR
	B Length of hose reel hose	Hose Reels	30 m	MR
	C Nozzle diameter	Hose Reels	5mm	MR

07. Automatic Fire Detection and Alarming System:				
A	Type of detectors	Smoke Type	Provided	MR
B	Location of main panel	Ground Floor	Provided	MR
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	Required	Provided	MR
E	Hooter's Location	Required	All Floors	MR
08.	MOEFA:	Required	Provided	MR
09	Public Address System:	Required	Provided	MR
10.	Automatic Sprinkler System:			
A	Basement	N/A	N/A	N/A
B	Ground Floors	N/A	Provided	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:			
A	Size of riser/down-comer	100 mm	Provided	MR
B	Number of hydrants per floor	01	Provided	MR
C	Hose box	01	Provided	MR
12.	Yard Hydrants:			
A	Total number of hydrants	-NA-	-NA-	-NA-
B	Hose box	-NA-	-NA-	-NA-
13.	Pumping Arrangements:			
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump	900 LPM	Provided	MR
B	Head of the pump	Old case	Provided	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	-NA-	-NA	-NA-
B	Draw-off connection	-NA-	-NA	-NA-
C	Fire service inlet	-NA-	-NA	-NA-
D	Access to tank	NA	-NA	NA
E	Overhead tank capacity	5,000 Liters	25,000 liters.	MR
15.	Exit Signage:	Required	Provided	MR
16.	Provision of Lifts:			
A	Pressurization of lift shaft	-NA-	-NA-	-NA-
B	Pressurization of lift lobby	-NA-	-NA-	-NA-
C	Communication in lift car	-NA-	-NA-	-NA-
D	Firemen's grounding switch	-NA-	-NA-	-NA-
E	Lift signage	-NA-	-NA-	-NA-

M/24

17.	Standby Power Supply:	Required	Provided	MR
18.	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19.	Fire Control Room:			
A	Detector system panel	-NA-	-NA-	-NA-
B	Flow switch panel	-NA-	-NA-	-NA-
C	PA system panel	-NA-	-NA-	-NA-
D	Battery backup	-NA-	-NA-	-NA-
E	Building floor plans	-NA-	-NA-	-NA-
20.	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/EH/SZ/2022/SZ/351 dated 16/12/2022, renewal under Rule 37 of the Delhi Fire Service rules 2010, is recommended to be renewed.

Last Date- 30/01/2026.

Signature of the Inspecting Officer
Name: Yashwant Singh Meena
Designation: - ADO/BCP

DO/SD

9/1/26

~~Secretary~~

~~Principal~~
12/1/26

~~A. K. MALIK~~

~~Principal Director~~

My. Cr to Issue.

~~My. Cr to (SZ)~~

14-1-26

~~A. K. MALIK~~
16/1/26

~~DO/SD~~

9/1/26

~~ADO/BCP~~

P.T.O