

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2025/SZ/ 110  
To

Dated: 10/03/2025

The Addl. Commissioner of Police,  
1<sup>st</sup> Floor PS Defence Colony,  
New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Jubilant Foodworks Ltd, Dominos Pizza located at Ground Floor, U-22 CGS and U-22 EGS Uttam Nagar West Metro Station, Delhi

Sir,

This has reference to with **MCD Portal ID No 2025021701971 dated 17/02/2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03.03.2025 in the presence of Mr. Danish to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. There are two exit doors having width of 1.50 mtr & 1.40 mtr against the required width of 1.50 mtr each.
2. First aid hose reel provided but found not working.
3. Internal hydrant provided but found not working.
4. Terrace level fire fighting pump capacity 450 LPM Not Provided.
5. Overhead water tank capacity 20,000 ltrs not provided.
6. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
