



c157
75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 144

Dated: 01/04/2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s Udhav Palace Guest House located at Prop. No. 3317 to 3321, Bagichi Habib Bux, Gali Hari Mandir, Pahar Ganj, New Delhi-110055

Sir,

Please refer to online application No. **2025031503539** dated 15/03/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 24/03/2025 in the presence of Sh. Nandu Vajpai (Caretaker) of the guest house. During course of inspection, the shortcomings observed are as below.

1. First aid hose-reel provided but non-functional.
2. Manually operated electric fire alarm (MOEFA) found non-functional.
3. Terrace level fire pump provided but non-functional.
4. Overhead water storage exclusively for firefighting, used for domestic purposes.
5. Lift signage found removed.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Ms. Sunita Goel, M/s Udhav Palace Guest House located at Prop. No. 3317 to 3321, Bagichi Habib Bux, Gali Hari Mandir, Pahar Ganj, New Delhi-110055