



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F6/DFS/MS/2025/WEST ZONE/ EH/502

Dated 31/12/2025

To,

The Commissioner (MCD),
SPM Civic Centre,
JL Nehru Marg, Delhi-110002

Sub:- Special Drive for surprise inspection in r/o eating houses / restaurants in Delhi from Fire prevention & Fire Safety point of view.

Sir,

As per the office order No. F6/DFS/HQ/2025/2127 dated 10/12/2025, surprise inspection of eating house namely Udupi Darshini located at Property No.-D-2/8, Ground floor, Model Town-III, Delhi-110009 was conducted by officer of this department on dated 17/12/2025 in the presence of Sh. Upendra (Captain) to ascertain the availability & operability of the Fire prevention & Fire Safety measure provided in the building and following observation were made during the time of inspection.

1. Fire Pump of capacity 450LPM provided but found nonfunctional.
2. Internal Hydrant & Hose Reel Hose provided but found damaged / nonfunctional.

The above-mentioned shortcomings should be complied latest by 7 days (i.e.24/12/2025).

Keeping in view of above, Fire Safety Certificate issued by this department vide letter F6/DFS/MS/2024/EH/10 Dated 08/01/2024 to the **restaurant will remain suspended** until the compliance of the above mentioned shortcomings. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully

LIV
31/12/25
(S.K. Dua)
Dy. Chief Fire Officer (WZ)

Copy to:-

1. Sh. Upendra (Manager), Udupi Darshini located at Property No.-D-2/8, Ground floor, Model Town-III, Delhi-110009.