

C-102

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F.6/DFS/MS/Parking/ECN/2026/256

Dated: 25 / 06 / 2026

To

The Assistant Engineer (Bldg. Department),
Municipal Corporation of Delhi,
Dr. SPM, Civic Centre, New Delhi-02.

Sub: Regarding issuance of Fire Safety Certificate in respect of M/s Under Ground Multilevel Car Parking at Parade Ground Subash Marg Delhi.

Sir,

This is in reference to online application ID No. 52026050502684 (Online) on the subject cited above. In this connection, it is to inform you that the inspection of the premises was conducted by the officer concerned of this department in the presence Mr. M. K. Yadav (J.E. Electrical) on dated 11.06.2026 to verify the fire safety measures installed in the building and observed that building is comprised of Three Basements only. During inspection following shortcoming were observed:

1. Fire Control Room was found locked.
2. MOEFA are found broken and non functional.
3. Fire checked door handle found broken.
4. Exit signage not provided at some places.
5. Smoke detectors found non functional.
6. Fire Extinguisher found removed at some places.
7. Automatic operational pump found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service
dc

Copy to:-

1. The Manager, M/s Under Ground Multilevel Car Parking at Parade Ground Subash Marg Delhi.