



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6/DFS/MS/CGHS/2025/SZ/ 298

Dated: 24 / 02 / 2025

To

The Manager,  
The Bhagwan Shree Gومتेश्वर Ji CGHS Ltd.,  
Plot No. 3A, Sector-2,  
Dwarka, New Delhi-110075

**Sub: Regarding renewal of Fire Safety Certificate in r/o Unique Insurance CGHS Ltd.  
located at Plot No. 38, Sector-6, Dwarka, New Delhi-110075**

Sir,

This has a reference to your email dated 13/02/2025, on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 18/02/2025 in the presence of Col. Nutan Prashant (Fire Incharge) to verify the compliance of the shortcomings issued vide letter No. F6/DFS/MS/CGHS/SZ/2024/555 dated 30/09/2024 and observed that the shortcomings mentioned at serial number 2 & 3 of the said letter is yet to be complied.

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to comply with the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Jt. Director (Bldg.), Delhi Development Authority, Vikas Sadan, INA, New Delhi-23

C-49  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI – 110001**

NO. F6/DFS/MS/CGHS/SZ/2024/ 555

DATED: 30/09/2024

To,

The President,  
Unique Insurance CGHS Ltd.  
Plot No 38, Sector – 06, Dwarka,  
New Delhi 110075.

**Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Unique Insurance CGHS Ltd. Located at Plot No 38, Sector – 06, Dwarka, New Delhi 110075.**

Sir,

This is in reference to your letter No. UA/2024/11 dated 07/09/2024 on the subject cited above. In this connection it is to inform to you that the above said premises was inspected by the officer concerned of this department on 23/09/2024 in the presence of Mr. Ramsuman (Manager) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. Only one fire extinguishers of ABC type 5Kg capacity is found provided against required two fire Extinguishers at some floors.
2. MOEFA & PA system found nonfunctional.
3. Terrace pumps found nonfunctional on auto mode.
4. Exit signage's found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter. The occupancy of the building premises without valid Fire Safety Certificate is on the risk and responsibility of the management committee.

Yours faithfully,

(Atul Garg)  
(Director)  
Delhi Fire Service

Copy to:-

1. The Joint Director (Building), DDA, Vikas Sadan, INA, New Delhi.