

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2025/ 677

Dated: 19/05/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **United English Medium School** located at **17-A, Raj Niwas Marg, Delhi – 110054**, comprised of **ground + 01 upper floor** was granted FSC by this department vide letter No. F6/DFS/MS/School/NDZ/2022/497 dated 09.05.2022. The premises was re-inspected by the officer concerned of this department on 09.05.2025 in the presence of Mr. Sudhir Bux (Principal) and found that the school building have deemed complied with the fire prevention and fire safety requirement in accordance with circular issued by the D.O.E. dated 01.03.2011 that the building is fit for occupancy class (**Group- B**) "**Educational Building**" with effect from ....19/05/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....19/05/2025.....at New Delhi by.

(Atul Garg)  
 Director  
 Delhi Fire Service  
 Tel: 011-23414000  
 OK  
 19/5

**Copy to:-**

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, United English Medium School at 17-A, Raj Niwas Marg, Delhi – 110054.

**Conditions for the validity of Fire Safety Certificate:-**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & address of the building	United English Medium School located at 17-A, Raj Niwas Marg, Delhi – 110054.		
2	Building is comprised of	Ground + 01 upper floors		
3	Type of occupancy	"Education Building" (Group - B)		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2022/497 dated 09.05.2022		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	09.05.2025		
8	Name of the inspecting officers	ADO (SPM)		
9	Name of the designation of officer from the building side	Mr. Sudhir Bux (Principal)		
10	Year of construction	2000		
11	Applicant's letter no.	Outdoor Diary No. 796 dated 21.04.2025		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	As Per Education Circular	Provided at Site	Remarks MR/ NMR
1	<b>Access To Building:</b>			
	Road width	Approachable	06 mtrs.	MR
	Gate width	06 mtrs.	05 mtrs.	MR
	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	02 nos.	02 nos.	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	1.50 mtrs.	1.10 & 1.20 mtrs.	MR
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	NA	NA	NA
E	Width of corridor	NA	NA	NA
F	Door size	1.0 mtr.	1.0 mtr.	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
A	Basements	30 ACPH (NA)	NA	NA
B	Upper Floor	12 ACPH	NA	NA



<b>5. Fire Extinguisher:</b>				
A	Total numbers	06 nos.	06 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI marked	ISI marked	MR
<b>6 First-Aid-Hose Reels:</b>				
A	Total numbers of each floor	NA	NA	NA
B	Length of hose reel hose	NA	NA	NA
C	Nozzle diameter	NA	NA	NA
<b>7 Automatic Fire Detection And Alarming System:</b>				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
8	MOEFA:	NA	NA	NA
9	Public Address System:	NA	NA	NA
<b>10 Automatic Sprinkler System:</b>				
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
<b>11 Internal Hydrants:</b>				
A	size of riser/down-comer	NA	NA	NA
B	Number of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
<b>12 Yard Hydrants:</b>				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
<b>13 Pumping Arrangements:</b>				
A	Ground level			
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
i)	Pump house access	NA	NA	NA
B	Terrace level			
a)	Discharge of pump	NA	NA	NA
b)	Head of the pump	NA	NA	NA
c)	Power supply	NA	NA	NA
d)	Auto starting of pump	NA	NA	NA

14	<b>Captive Water Storage For Fire Fighting:</b>			
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	NA	NA	NA
15	<b>Exit Signage:</b>			
		NA	NA	NA
16	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	<b>Standby Power Supply:</b>			
		NA	NA	NA
18	<b>Refuge Area:</b>			
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
19	<b>Fire Control Room :</b>			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	Pa system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	<b>Special Fire Protection Systems For Protection of Special Risks, If Any:</b>		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as per D.O.E Circular FSC issued vide letter no. F6/DFS/MS/School/NDZ/2022/497 dated 09.05.2022 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

Accordingly, DFA is put up for approval & signature please.

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

DO/CD)

12/5/25

Sy. COO (NDZ)

12/05/25

C.F.O.

14/5/2025

Director

Director (DFS)

G.T. letter is put up for signature, Please.

15.05.2025