



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/8
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/675

Dated: 21/08/2025

To,

The Principal,
Vanasthali Public School,
G – Block, Preet Vihar, Delhi – 110092.

Subject: - Regarding grant of Fire Safety Certificate in r/o Vanasthali Public School located at G – Block, Preet Vihar, Delhi – 110092.

Sir,


This has a reference to your Outdoor Dairy No. 4269 dated 29/07/2025 on the subject cited above. In this connection, it is to inform you that school was inspected by the officer concerned of this department on 07/08/2025 in the presence of Ms. Neha (Principal) and observed that school building comprised of Ground plus one upper floor & Terrace floor 02 SPS rooms.

Following shortcomings were observed during time of inspection:

1. Hose reel provided but found not functional.
2. Fire pump of capacity 220 LPM provided but not functional.
3. Overhead water storage tank of 500 liters provided against the requirement of 2500 liters.
4. 02 SPS rooms on terrace floor to be removed.

In view of above shortcomings, the application for **issuance of Fire Safety Certificate is rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

You're faithfully,


21/8/2025

VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, GNCT of Delhi, Old Secretariat, Civil Lines, Delhi-110054.