

C 42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2025/SZ/1332

Dated: 20/11/2025

FIRE SAFETY CERTIFICATE

Certified that the Vandana Kindergarten School located at Sec. 10, Phase- 1, Dwarka, New Delhi- 110075, is comprised of ground floor plus two upper floors, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/SZ/2022/School/491 dated 09.05.2022. The school building was re- inspected by the officer concerned of this department on dated 07.11.2025 in the presence of Sh. Hitesh (Caretaker), and found that the school building have complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (ground plus two upper floors) is fit for occupancy class "Educational Building" w.e.f. 20/11/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 20/11/2025 at New Delhi by.


(A. K. Malik)
Dy. Chief Fire Officer
9/11/25

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Chairman, Vandana Kindergarten School located at Sec. 10, Phase- 1, Dwarka, New Delhi- 110075.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/20

INSPECTION REPORT

1. Name & address of the building : Vandana Kindergarten School at Sector- 10, Phase- 1, Dwarka.
New Delhi- 110005.
2. Building comprised of : Ground plus two upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/SZ/2022/School/491 dated 09.05.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 07.11.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers : Sh. Hitesh (Caretaker)
- From the building side :
10. Year of Construction : 2011-12
11. Applicant's letter No. : Nil, dated 09.10.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dated 09.05.2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 m 4.5 m N/A	06 m Provided N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02 No	02 No's	M/R
	<ul style="list-style-type: none"> Upper Floors Basements 	N/A	N/A	N/A
	b. Width of staircases	1.50 m each	Provided	MR
	<ul style="list-style-type: none"> Upper Floor Basements 	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	01 nos.	M/R
		1.50 m	1.60 m	M/R
	e. Width of Corridor	1.0 m	Provided	M/R
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A Required N/A N/A N/A	N/A Sealed N/A N/A N/A	N/A MR N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A 12 ACPH	N/A Natural ventilation	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	15Nos. ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 nos. 30 M 5 mm	Provided Provided Provided	M/R M/R M/R

18.

V

N/22

	Standby power supply	N/A	N/A	N/A
N/8.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/SZ/2022/School/491 dated 09.05.2022 is recommended to be renewed under rule 37, of the Delhi Fire Service Rules, 2010.

Signature of the Inspecting Officer

Name: - R.K. Yadav

Designation: - ADO (SRD)

DO (SW)

16/11/25

RAJINDER ATWAL

My. cfo (sz)

16/11/25

A.K. MALIK

Principal Director

My. cfo to S.D.

11/11/25

My. cfo (sz)

17/11/25

A.K. MALIK

17/11

DO (SW)

400 (GWA)

PFO