

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2025 /School/WZ/ 41

Dated 22/01/2025

FIRE SAFETY CERTIFICATE

Certified that the Vedic Public School located at Khera Garhi, Delhi-110082 comprised of Ground floor only was issued FSC by this department vide letter No F6/DFS/MS/School/2015/WZ/1101 dated 26.06.2015. The premises was re-inspected by the officer concerned of this department on 08.01.2025 in the presence of Sh. Mohit, and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from .... 22/01/2025.. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ..... 22 ... 2.5at New Delhi by

(Aral Garg) Director

Ph. 011-23414000

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054

2. The Principal, Vedic Public School located at Khera Garhi, Delhi-110082.

## Conditions for the validity of Fire Safety Certificate:

- 1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3. The trained fire fighting staff should be available round the clock.
- 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <a href="https://www.dfs.delhigovt.nic.in">www.dfs.delhigovt.nic.in</a>
- 8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building: Vedic Public School located at Khera Garhi, Delhi- 110082.

 Type of Occupancy
 Building Comprised of Educational 4. Type of Case Ground floor only Renewal

5. Details of Previous NOC F6/DFS/MS/School/2015/WZ/1101 dated 26/06/2015 6. Fire Safety directives letter No : DOE circular No. 3298-3398 dated 01/03/2011

08/01/2025

7. Date of inspection 8. Name of Inspecting Officer R.K.Sinha, ADO (BW)

9. Name and designation of officers

From the building side Sh. Mohit

S.	11. Applicant's letter No. :	E Mail ID dated 30/12 DOE	Provided at site	Remarks MR/NMR		
No.		Requirement		MINIMA		
1.	Access to building		Provided	MR		
	Road width	6 m	Directly Accessible	MR		
	Gate width	4.5 m	NA NA	NA		
	Width of internal road	NA	IVA			
2.	Number, Width, Type & Arrangement of Exits					
	Number of staircases		NA	NA		
	Upper Floors	NA	NA NA	NA		
	Basements	NA				
	Width of staircases		NA	NA		
	Upper Floor	NA	NA NA	NA		
	Basements	NA NA	INA .			
	Protection of exits		NA	NA		
	Fire check door	NA		NA		
	The second secon	NA	NA			
	Pressurization  No. of continuous staircases to	NA	NA	NA		
	terrace	NA	NA	NA		
	Width of Corridor	1 m	Provided	MR		
	Door Size	• •••				
3.	Compartmentation		- NA	NA		
J.	Fire check door	NA	NA	77.55		
		NA	NA	NA		
	Sealing of electrical shafts	NA	NA	NA		
	Fire Rating of shaft door	NA	NA	NA		
	Water Curtain	NA	NA	NA		
	Fire Dampers					
4.	Smoke Management System	NA -	NA	NA		
	Basements		NA	NA		
	Upper floors	NA				
5.	Fire Extinguishers		Provided	MR		
	Total numbers	05	Provided	MR		
	Types	ABC Type		MR		
	IS marking	Required	Provided	IVIIX		
	First-Aid Hose Reels		NA	NA		
•	Total numbers on each floor	NA	NA NA	NA		
	Length of hose reel hose	NA		NA		
	Nozzle diameter	NA	NA	NA		
	Automatic fire detection and alarming system					
-		NA	NA	NA		
	Type of detectors	NA	NA	NA		
	Location of Main Panel	NA NA	NA	NA		
	Location of Repeater Panel	NA NA	NA NA	NA		
-	Alternate source of power			311		
	Hooters' Location	NA	NA	NA		

1		1
	1	1

		NY				
8.	MOEFA	NA	NA	NA		
9.	Public Address System	NA NA	NA	NA		
10	. Automatic Sprinkler System			X		
-	Basement			NA NA		
	Ground Floor	NA NA	NA NA	NA NA		
		NA	NA	NA NA		
11	Sprinkler above false ceiling	NA	NA	NA NA		
11	. Internal Hydrants					
	Size of riser/down-comer	NA	NA	NA NA		
	Number of hydrants per floor	NA	NA	NA		
	Hose Box	NA	NA	NA NA		
12.	. Yard Hydrants					
	Total number of hydrants	NA	NA	NA		
	Hose Box	NA	NA	NA		
13.	Pumping Arrangements			1 15		
	Ground Level			1		
	Discharge of main Pump	NA	NA	NA		
	Head of Main pump	NA NA	NA NA	NA NA		
	Number of main pumps	NA	NA	. NA		
	Jockey Pump out put	NA NA	NA NA			
	Jockey pump head	NA NA	NA NA	NA NA		
	Standby Pump out put	NA NA	NA NA	NA NA		
	Standby Pump Head	NA NA	NA NA	NA NA		
	Auto Starting/Manual Stopping	NA NA	NA NA	NA NA		
	Pump House Access	NA NA	NA NA	NA NA		
	Terrace level					
	Discharge of pump	NA	NA			
	Head of the pump	NA NA	NA NA	NA		
				NA		
	Power Supply	NA	NA	NA		
14.	Auto Starting of pump  Captive Water Storage for fire fighti	NA	NA	NA		
				TAIG T		
	Underground tank capacity	NA	NA	NA		
	Draw-off connection	NA	NA	NA		
	Fire service inlet	NA '	NA	NA NA		
	Access to tank	NA '	NA	NA NA		
_	Overhead Tank capacity	NA	NA			
5.	Exit Signage.	NA	NA NA	NA NA		
6.	Provision of Lifts.					
	Pressurization of Lift Shaft	NA				
	Pressurization of Lift lobby	NA NA	NA NA	NA		
	Communication In lift Car	NA NA	NA NA	NA		
	Fireman's Grounding Switch	NA NA	NA NA	NA		
	Lift Signage	NA NA		NA		
7.	Standby power supply	NA NA	NA	NA		
-		INA	NA	NA		
l.	Refuge Area.					
ĺ	Total Area	NA	NA			
-	Location	NA	NA NA	NA		
	Fire Control Room		M	NA		
	Detector System Panel	NA	NA			
	48.07	0/	NA	NA		

9/

1	Flow Switch Panel	NA	NA	NA
1	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
0.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electric meter and electrical panel are installed at safer location.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/School/2015/WZ/1101 dated 26/06/2015.

> Signature of Inspecting Officer Name: Rajeev Kumar Sinha Designation: ADO/B.W.

DOFOI .. BRED .. I. H. I. I. DOWN

ADOJANO EN. FT LECTE - 1 Son For son please