



No. F6/DFS/MS/School/NDZ/2025/ 227

Dated: 10/03/2025

FIRE SAFETY CERTIFICATE

Certified that **Vedic Public School** located at **R-73, East Vinod Nagar, Main Road Khichripur, Delhi-110091**, building comprised of Ground plus one upper floor only, owned/ occupied by **Vedic Public School** was issued Fire Safety Certificate by this department vide letter No. F6/MS/DFS/06/2558 dated 15/09/2006. The school building was re-inspected by the officer concerned of this department on 01/03/2025 in presence of Mr. Jagdish Chandra (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 and the school is fit for occupancy class **"Educational Building"** (Group - B) for ground plus one upper floor only with effect from 10/03/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010. Subject to conditions, printed overleaf.

Issued on 10/03/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, 15th floor, Civic Centre, New Delhi-110001.
2. The Principal, Vedic Public School, R-73, East Vinod Nagar, Main Road Khichripur, Delhi-110091.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry e
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency. of
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible. e
5. At the time of inspection second floor is being used for resident purpose only.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned. y
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any. n
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in. ii

N/02

INSPECTION REPORT

1	Name & address of the building	Vedic Public School located at R-73, East Vinod Nagar, Main Road Khichripur, Delhi-110091.		
2	Building is comprised of	Ground plus one upper floors only.		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/MS/DFS/06/2558 dated 15/09/2006.		
6	Fire safety directives letter no.	Circular No. 262 - 362 dated 17/01/2005		
7	Date of inspection	01/03/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO / Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. Jagdish Chandra (Manager)		
10	Year of construction	2000		
11	Applicant's letter no.	Outdoor Diary No.-12690 dated 19/02/2025		
S. No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building:			
	A Road width	6.0 mtrs.	6.0 mtrs.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 no.	02 nos.	MR (Old Case)
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.5 mtrs.	0.90 mtrs & 0.90 mtr.	MR (Old Case)
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no.	01 no.	MR
	E Width of corridor	N/A	N/A	N/A
	F Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4.	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A


5. Fire Extinguisher:					
	A	Total numbers	08 nos.	08 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:					
	A	Total numbers of each floor	N/A	N/A	N/A
	B	Length of hose reel hose	N/A	N/A	N/A
	C	Nozzle diameter	N/A	N/A	N/A
7 Automatic Fire Detection and Alarming System:					
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	Provided	MR
9	Public Address System:		N/A	Provided	MR
10 Automatic Sprinkler System:					
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:					
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12 Yard Hydrants:					
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:					
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	N/A	N/A	N/A
	B	Head of the pump	N/A	N/A	N/A
	C	Power supply	N/A	N/A	N/A
	D	Auto starting of pump	N/A	N/A	N/A

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	N/A	1,000 lit.
			Required	Provided
15	Exit Signage:			
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:			
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			

The fire protection system was randomly checked and tested and was found functional at the time of inspection.


Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/MS/DFS/06/2558 dated 15/09/2006, Renewal under rule 35(6) of the Delhi Fire Rules 2010 is recommended.

No file is pending with me before disposal of this case.


03/3/2025

Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (L.N)


D.O/ED



3/3/2025

Dy. C.F.O. / (RDZ)

Rivp
04/03/25

C.F.O.


5/3/2025

Director

C(m)/RT



P.T.O