GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/EH/2025/SZ/ 436

Dated: 18/11/2025

To,

Sh. Praveen Gulati, M/s Veg Gulati The Dessart Gallery, (A Unit of Gulati Foods Pvt. Ltd.), S-32, First and Second Floor, Green Park Market, Green Park, Delhi- 110016.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Veg Gulati The Dessart Gallery (A Unit of Gulati Foods Pvt. Ltd.), S-32, First and Second Floor, Green Park Market, Green Park, Delhi- 110016.

Sir,

This has reference to online application received through MCD portal vide ID-2025101114133 dated 14/10/2025 on the subject cited above. In this connection, it is to inform you that the above said assembly building was visited by the officer concerned of this department on 28/10/2025 to see the compliance of requisite fire safety measures. Sh. Kuldeep (Manager) was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. Terrace level jockey pump not found in auto mode.

2. Exit signage's found removed at some places.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

Dy. Chief Fire Officer