

c/86

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/WZ/GH/2025/ 31

Dated: 17/01/2025

To,

Mr. Rajender & Charanjeev,
House No.1734-14, Gali Partap,
Pahar Ganj,
New Delhi-110055.

Sub: Renewal of FSC in r/o M/s Venus International, located at 1925 to 1927, Gali No.10, Chuna Mandi, Pahar Ganj, New Delhi-110055.

Sir,

This is reference to online application no. 2025010300108 dated 03.01.2025 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **10.01.2025**, in presence of **Mr. Haseem (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace fire pumps were not found in auto mode.
2. Hose-reel found non-functional due to leakage near fire service inlet.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph: 011-23414000

Copy To:-

1. MCD Portal Id- 2025010300108 dated 03.01.2025.

ok
by