

C-63

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2025/353

Dated:-14..08./2025

To

The Manager
M/s Venus Guest House,
A-282, N.H.-8 Mahipalpur,
New Delhi-110037.

Sub: Regarding issuance of FSC in r/o M/s Venus Guest House, A-282, N.H Mahipalpur, New Delhi-110037


Sir,

This has reference to online id no. 2025071411351 dated 15/07/25, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 31/07/25 in the presence of Manager and following shortcomings were observed:-

1. Hose reel, hydrant & pump found non- functional
2. Detector found nonfunctional.
3. The basement is being used for restaurant, same shall be used as BBL concerned.

In view of above shortcomings, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to

The Commissioner, MCD, Civic Center, New Delhi.