



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 26

Dated: 15/01/2025

FIRE SAFETY CERTIFICATE

Certified that the Venus Public School located at Plot No. 01, Opposite 1457 Outram Line GTB Nagar, Delhi-110009 comprised of Ground & first floor only owned/ occupied by Venus Public School was issued Fire Safety Certificated by this department vide letter no. F6/DFS/MS/School/2021/WZ/1069 Dated 24.12.2021. The premises was inspected by the officer concerned of this department on 03.01.2025 in presence of Mr. Sameer Kumar (Manager) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational (School)" with effect from ...15/01/2025. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on15/01/2025 at New Delhi by.

(Atul Garg)
Director

Ph:-011-23414000

Copy to :-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.
2. The Manager, Venus Public School located at Plot No. 01, Opposite 1457 Outram Line GTB Nagar, Delhi-110009

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Venus Public School at Plot No-1, Opp. 1457, Outram Lane, G.T.B Nagar, Delhi-110009.
2. Composition of building : Ground & First floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2021/WZ/1069 Dated : 24.12.2021
6. Fire Safety directives letter No : Director of Education Letter dated 01.03.2011
7. Date of inspection : 03.01.2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mr. Sameer Kumar (Manager)
10. Year of Construction : Since- 1997
11. Applicant's letter No. : Letter No. Nil dated 23.12.2024

	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)	Provided at site	Remarks MR/NMR
1	Access to building			
		06m	06m	MR
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Directly Accessible NA	Directly Accessible NA	MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	01	01	MR (being old case)
	<ul style="list-style-type: none"> Upper Floors Basements 	NA	NA	NA
	b. Width of staircases	1.50 m	1.55m	MR
	<ul style="list-style-type: none"> Upper Floors Basements 	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	01m double door	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		Required	Natural Ventilated	MR
5	Fire Extinguishers			

	<ul style="list-style-type: none">Total numbersTypesISI marking	04nos	06nos	MR
		ABC/Co2	ABC-06	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none">Total numbers on each floorLength of hose reel hoseNozzle diameter	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none">Type of detectorsLocation of Main PanelLocation of Repeater PanelAlternate source of powerHooters' Location	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA			
		NA	NA	NA
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none">BasementUpper FloorSprinkler above false ceiling	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none">Size of riser/down-comerNumber of hydrants per floorHose Box	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none">Total number of hydrantsHose Box	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none">Ground Level<ul style="list-style-type: none">Discharge of main PumpHead of Main pumpNumber of main pumpsJockey Pump out putJockey pump headStandby Pump out putStandby Pump HeadAuto Starting/ Manual stoppingPump House AccessTerrace level<ul style="list-style-type: none">Discharge of pumpHead of the pumpPower SupplyAuto Starting of pump	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none">Underground tank capacityDraw-off connection	NA	NA	NA
		NA	NA	NA

	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/School/2021/WZ/1069 Dated: 24.12.2021

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

D.B. Mukharjee (DO/NW)

DO/MS/2021/WZ/1069
Dated: 24/12/2021

08/01/2025

8/1

9/01/2025
Director

ADO/RN

cont - P.T.O.