

C-30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/School/NDZ/2025/127

Dated: 24 / 02 / 2025

To

The Principal,
Victoria Public Sr. Sec. School,
A-5, Brijpuri, Wazirabad Road, Delhi-110094.

Sub: Regarding Fire Safety Certificate in r/o Victoria Public Sr. Sec. School, A-5, Brijpuri, Wazirabad Road, Delhi-110094.

Sir,

This has reference to outdoor dairy No. 11891 dated 28/01/2025 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 15/02/2025 in the presence of Mrs. Madhu Sharma (Vice-Principal) and observed that at present school is comprised of Ground plus three upper floors only. Fire safety measures were checked as per the rules and following shortcomings were observed.

1. Hose Reel Hose provided but nonfunctional.
2. Fire pump of 450 LPM provided but nonfunctional.
3. Fire Pump not on auto mode.
4. Exit Signage found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.