



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

1209




No F 6/DFS/MS/GH/2025/WZ/ 538

Dated: 07 / 11 / 2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Vishwa Yuvak Kendra (A Unit of Indian Youth Centres Trust) at Circle Road, Chanakyapuri, New Delhi-110021, comprised of Basement, Ground & 04 Upper Floors owned/ occupied by M/s Vishwa Yuvak Kendra (A Unit of Indian Youth Centres Trust), was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2021/SZ/GH/536 dated 20/12/2021. The premises was inspected by the officer concerned of this department on 24/10/2025 in the presence of Sh. Manoj Kr. Rai and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy class "Residential (Group-A)" with effect from...07/11/2025... for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010:

Issued on 07/11/2025 at New Delhi


(A. K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service
11/11/25

Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, with a request to ensure the occupancy as detailed above deviation and if any. Online Portal ID No-2025100513959 dated 17/10/2025.
2. The Authorized Signatory, Vishwa Yuvak Kendra (A Unit of Indian Youth Centres Trust) at Circle Road, Chanakyapuri, New Delhi-110021.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. Basement shall not be used for any other purpose except as specified in UBBL, subject to permission from concerned local authority.
6. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
7. The owner/occupier shall submit a declaration every y year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the MCD portal along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Vishwa Yuvak Kendra (A Unit of Indian Youth Centres Trust) at Circle Road, Chanakyapuri, New Delhi-110021.
2. Type of Occupancy : Residential (Group A)
3. Type of Case : Renewal
4. Composition of building : Basement, Ground & 04 upper floors,
5. Details of Previous FSC : F6/DFS/MS/2021/SZ/GH/536 dated 20/12/2021.
6. Fire Safety directives letter No : Nil
7. Date of inspection : 24/10/2025
8. Name of Inspecting Officer : ADO (Rohini)
9. Name and designation of officers
10. From the building side : Mr. Manoj Kr. Rai
11. Year of Construction : 1969
12. Applicant's letter No. : Online MCD Portal ID No.2025100513959 dated 17/10/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement As Per Rules 35 (6)	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.50m	4.50m	MR
	• Width of internal road	N.A	N.A	N.A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Upto 1 st floor= 02nos. 1 st floor to terrace=03nos.	Provided	MR
	• Basements	02nos	Provided	MR
	b. Width of staircases			
	• Upper Floor	02nos. of 1.25m	1.27m, 1.23m & 60cm from 1 st floor to terrace	MR
	• Basement	1.25m	1.50m & 2.27m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N.A	N.A	N.A
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	N.A	N.A	N.A
	f. Door Size	01mtr	01mtr	MR
3.	Compartmentation			
	• Fire check door	N.A	N.A	N.A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N.A	N.A	N.A
	• Water Curtain	N.A	N.A	N.A
	• Fire Dampers	N.A	N.A	N.A
4.	Smoke Management System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR

No/64

5.	Fire Extinguishers			
	• Total numbers	24nos.	30 No's	MR
	• Types	ISI marked	ABC&WCO ₂	MR
	• IS marking	Required	Provided	MR

6.	First-Aid Hose Reels			
	• Total numbers on each floor	02	02nos	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5 mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N.A	N.A	N.A
	• Location of Main Panel	N.A	N.A	N.A
	• Location of Repeater Panel	N.A	N.A	N.A
	• Alternate source of power	N.A	N.A	N.A
	• Hooters' Location	N.A	N.A	N.A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground Floor	N.A	N.A	N.A
	• Sprinkler above false ceiling	N.A	N.A	N.A
11.	Internal Hydrants			
	• Size of riser/down-comer	N.A	N.A	N.A
	• Number of hydrants per floor	N.A	N.A	N.A
	• Hose Box	N.A	N.A	N.A
12.	Yard Hydrants			
	• Total number of hydrants	N.A	N.A	N.A
	• Hose Box	N.A	N.A	N.A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	900 LPM	Provided	MR
	➤ Head of Main pump	70 m	Provided	MR
	➤ Number of main pumps	1 No's	Provided	MR
	➤ Jockey Pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby Pump out put	N.A	N.A	N.A
	➤ Standby Pump Head	N.A	N.A	N.A
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM & 180 LPM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

MR	MR	14.	Captive Water Storage for fire fighting			
			<ul style="list-style-type: none">Underground tank capacity	50,000 LTR	Provided	MR
			<ul style="list-style-type: none">➤ Draw-off connection	Required	Provided	MR
			<ul style="list-style-type: none">➤ Fire service inlet	Required	Provided	MR
			<ul style="list-style-type: none">➤ Access to tank	Required	Provided	MR
			<ul style="list-style-type: none">Overhead Tank capacity	10,000 ltr	10,000ltr + 10,000ltr	MR
		15.	Exit Signage.	Required	Provided	MR
		16.	Provision of Lifts.			
			<ul style="list-style-type: none">Pressurization of Lift Shaft		N.A	N.A
			<ul style="list-style-type: none">Pressurization of Lift lobby	N.A	N.A	N.A
			<ul style="list-style-type: none">Communication In lift Car	N.A	N.A	N.A
			<ul style="list-style-type: none">Fireman's Grounding Switch	N.A	N.A	N.A
			<ul style="list-style-type: none">Lift Signage	N.A	N.A	N.A
		17.	Standby power supply	Required	Provided DG	MR
		18.	Refuge Area.			
			<ul style="list-style-type: none">➤ Total Area	N.A	N.A	N.A
			<ul style="list-style-type: none">➤ Location	N.A	N.A	N.A
		19.	Fire Control Room			
			<ul style="list-style-type: none">Detector System Panel	N.A	N.A	N.A
			<ul style="list-style-type: none">Flow Switch Panel	N.A	N.A	N.A
			<ul style="list-style-type: none">PA System Panel	N.A	N.A	N.A
			<ul style="list-style-type: none">Batter backup	N.A	N.A	N.A
			<ul style="list-style-type: none">Building Floor Plans	N.A	N.A	N.A
		20.	Special Fire Protection System for Protection of special Risks, if any:	N.A	N.A	N.A

The Fire protection systems provided in the building were tested/checked at randomly and found in good working condition, at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures. **It is recommended for renewal for fire safety certificate** as required under the rules, renewal of FSC issued vide this department letter of even no. F6/DFS/MS/2021/SZ/GH/536 dated 20/12/2021, is recommended.

Signature of the Inspecting Officer

Name: Sh. C.L. Meena

Designation: ADO (Rohini)

DO (South)

[Signature]
28/10/25

[Signature]

[Signature]
29/10/25
A.K. MALIK
Principal Engineer

[Signature]
29/10/25
A.K. MALIK

[Signature]
By. Cfo (SZ)

By. Cfo to Jm
[Signature]
29/10/25