

49



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2025/School/ 755

Dated: 25/09/2025

To

The Authorized Signatory  
 Vidhya Devi Public School  
 Plot No- 34, Kh. No-17/4, Gali No-15,  
 Sawroop, Delhi-110042.

Sub: - Regarding grant of fire safety certificate in r/o Vidhya Devi Public School at Plot No- 34, Kh. No-17/4, Gali No-15, Sawroop , Delhi-110042.

Sir,

Please refer to your letter no- nil dated 02/09/2025 on the subject cited above. In this connection this is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 18/09/2025 in the presence of Mr. Devpal was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school premises is comprised of ground & first floor only. The observations/ shortcomings made are as under:-

1. Hose reel hose is not provided.
2. Terrace level fire pump capacity of 450lpm is not provided.
3. Terrace level fire water tank capacity of 10,000ltr is not provided.
4. Exit & floors signage's is not provided at strategic location in the school building.
5. Standby power supply is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

*[Signature]*  
 25/09/2025  
 Virendra Singh

Chief Fire Officer  
 Delhi Fire service

*[Signature]*

Copy to:-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.