



6-15

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/School/WZ/2025/ 1338

Dated:- 20/11/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Vidhya Devi Public School, located at Plot No. 34, Kh. No. 17/4, Gali No. 15, Sawroop Nagar, Delhi-110042, comprised of ground + 01 upper floor only, owned/occupied by Vidhya Devi Public School, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on 14/11/2025 in the presence of Sh. Devpal and that the building/premises is fit for occupancy class "Educational Building" Group B with effect from 20/11/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 20/11/2025 at New Delhi by

S.K. Dua  
20/11/25

Dy. Chief Fire Officer (WZ)

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Vidhya Devi Public School, located at Plot No. 34, Kh. No. 17/4, Gali No. 15, Sawroop Nagar, Delhi-110042.

**Conditions for validity of fire safety certificate:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name and address of the building: Vidhya Devi Public School, located at Plot No. 34, Kh. No. 17/4, Gali No. 15, Sawroop Nagar, Delhi-110042
2. Type of Occupancy : Educational, (Ground + 01 Upper Floor only)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 14/11/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (BN/RN)
8. Name and designation of Officer  
from the building side : Sh. Devpal
9. Year of Construction : 2025
10. Applicant's letter No. : nil dated 28/10/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per NBC (Part-IV)	Provided at site	Remarks MR/NMR
1.	Access of building	06 m	Provided	MR
	• Road width	4.5 m	Abut on road	MR
	• Gate width	NA	NA	NA
	• Width of internal road			
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02 nos.	Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 m each	Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	02 nos.	Provided	MR
	d. No of continuous staircase to terrace	1.5 m	Provided	MR
	e. Width Of Corridor	1.2 m	Provided	MR
	f. Door Size			
3.	Compartmentation	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System	NA	NA	NA
	• Basements	Required	Natural Ventilation	MR
	• Upper floors			
5.	Fire Extinguishers	04 nos.	Provided	MR
	• Total numbers	ABC & CO <sub>2</sub>	Provided	MR
	• Types	ISI Marked	Provided	MR
	• ISI marking			

QCA



6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found working at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/2025/School/755 dated 25/09/2025 found rectified.

Keeping in view of substantial compliance of the minimum standards of fire prevention and fire safety requirements under the rules, **grant of Fire safety Certificate is recommended** under rule 35 of the Delhi Fire service Rules 2010 under the DFS Act 2007.

Accordingly, DFA is prepared & put up for approval please.

*[Signature]*  
18/11/25  
Aman Kumar Lathar  
ADO (BW/RN)

*[Signature]*  
18/11/25  
By CFO/CWZ on leave  
By CFO/CWZ *[Signature]*  
18/11/25

Principal Director My. CFO to *[Signature]*  
*[Signature]*  
My. CFO (NDZ) *[Signature]*  
18/11/25  
*[Signature]*  
20/11/25

ADO/BW  
F.T. letter is put-up for your signature pl.

*[Signature]*  
20/11/25  
F.P. wing  
*[Signature]*

*[Signature]*  
20/11/25